

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED DEC 18 1969

STATE OF OREGON

(Please type or print) (Do not write above this line)

Bent 3295

State Well No. 11/5W-11

State Permit No.

STATE ENGINEER SALEM, OREGON

(1) OWNER:

Name VINEYARD MT. INC. Address 670 N.W. 21 STREET CORVALLIS, OREGON

(2) TYPE OF WORK (check):

New Well [] Deepening [] Reconditioning [x] Abandon []

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary [] Cable [x] Driven [] Jetted [] Bored []

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal [x] Irrigation [] Test Well [] Other []

(5) CASING INSTALLED:

8" Diam. from 0 ft. to 45 ft. Gage 350. Threaded [] Welded [x]

PERFORATIONS:

Perforated? [] Yes [x] No.

Type of perforator used

Size of perforations in. by in. perforations from ft. to ft.

(7) SCREENS:

Well screen installed? [] Yes [x] No

Manufacturer's Name Type Model No. Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 13 ft. below land surface Date 10/17/69 Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? [] Yes [x] No. If yes, by whom? Yield: gal./min. with ft. drawdown after hrs. Pump test to be made at later date. Bailer test 36 gal./min. with 20 ft. drawdown after 1 hrs. Artesian flow g.p.m. Date Temperature of water Was a chemical analysis made? [] Yes [x] No

(10) CONSTRUCTION:

Well seal—Material used Cement Grout Depth of seal 36 ft. Diameter of well bore to bottom of seal 12 in. Were any loose strata cemented off? [] Yes [x] No Depth Was a drive shoe used? [x] Yes [] No Did any strata contain unusable water? [] Yes [x] No Type of water? depth of strata Method of sealing strata off Was well gravel packed? [] Yes [x] No Size of gravel: Gravel placed from ft. to ft.

(11) LOCATION OF WELL:

County Benton Driller's well number 1/4 Section 11 T. 11S R. 5W W.M. Bearing and distance from section or subdivision corner

ORIGINAL WELL Depth 108 ft.

(12) WELL LOG:

Diameter of well below casing 8" and 6"

Depth drilled 108 ft. Depth of completed well 108 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

Table with columns: MATERIAL, From, To, SWL. Rows: Soil (0-2), CLAY, yellow (2-12), Sandrock, brown (12-98), BASALT, black (98-108)

AS this well was reamed from 6" to 8" well diameter we were not able to determine exact water strata. Estimates are that the water strata are between 50 and 98 ft.

Eight in drilling to 90 ft Six in drilling from 90 to 108

Work started Oct 13 1969 Completed Oct 17 1969 Date well drilling machine moved off of well Oct 17 1969

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Leroy W. Mutschler Date Nov 3, 1969 (Drilling Machine Operator)

Drilling Machine Operator's License No. 80

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME L.W. Mutschler well Drilling (Person, firm or corporation) (Type or print) Address 7555 N.W. Oak Creek Dr Corvallis, Oregon

[Signed] Leroy W. Mutschler (Water Well Contractor)

Contractor's License No. 237 Date Nov 3, 1969