NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

State Well No. Bent 3731
State Permit No. 11s/5w-20

(1) OWNER:
Name Edwin S Trowbridge
Address 3511 NW Roosevelt
Corvallis Ore 97330

(2) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

CASING INSTALLED: Threaded ☐ Welded ☒
6" Diam. from 0 ft. to 59 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS: Perforated? ☐ Yes ☒ No.
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☒ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 9 gal./min. with 68' ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water 52° Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used Bentonite
Well sealed from land surface to 20' ft.
Diameter of well bore to bottom of seal 9" in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal sacks
Number of sacks of bentonite used in well seal 3 sacks
Brand name of bentonite Yellowstone
Number of pounds of bentonite per 100 gallons of water lbs./100 gals.
Was a drive shoe used? ☐ Yes ☒ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Benton Driller's well number 76-16
¼ ¼ Section 20 T. 11S R. 5W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 158' ft.
Static level 89' ft. below land surface. Date 7/21/76
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 6"
Depth drilled 168' ft. Depth of completed well 168' ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
Clay Brown	0'	2'	
Sandstone Light Brown	2'	52'	
Sandstone Dark Brown	52'	86'	
Sandstone Gray	86'	158'	
Sandstone Broken-Brown	158'	168'	89'
Water Bearing			

RECEIVED
AUG-3 1976
WATER RESOURCES DEPT.
SALEM, OREGON

Work started 7/16 1976 Completed 7/21 1976
Date well drilling machine moved off of well 7/21 1976

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Robert E. Lord (Drilling Machine Operator) Date 8/1, 1976
Drilling Machine Operator's License No. 1025

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Howell Well Drilling (Person, firm or corporation) (Type or print)
Address Philomath Blvd Corvallis
[Signed] Bill Howell (Water Well Contractor)
Contractor's License No. 50 Date 8/2, 1976

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119