

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

RECEIVED MAY 25 1966 STATE ENGINEER SALEM OREGON

WATER WELL REPORT

STATE OF OREGON (Please type or print)

Bent 3907

State Well No. 11/5w-24

State Permit No.

(1) OWNER: Ralph Rowley Name A. D. Belknap Address Rt. 1 Corvallis, Oregon

(2) LOCATION OF WELL: County Benton Driller's well number 1/4 Section 24 T. 11s R. 5w W.M. Bearing and distance from section or subdivision corner.

(3) TYPE OF WORK (check): Dry Well [X] Deepening [] Reconditioning [] Abandon []

(4) PROPOSED USE (check): Domestic [] Industrial [] Municipal [] Irrigation [X] Test Well [] Other [] (5) TYPE OF WELL: Rotary [] Cable [X] Dug [] Driven [] Jetted [] Bored []

(6) CASING INSTALLED: 10" Diam. from 12 ft. to 58 ft. Gage STD

(7) PERFORATIONS: Perforated? [X] Yes [] No Type of perforator used acetylene torch Size of perforations 1/4 in. by 6 in. 110 perforations from 46 ft. to 58 ft.

(8) SCREENS: Well screen installed? [] Yes [X] No Manufacturer's Name Model No. Slot size Set from ft. to ft. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION: Well seal—Material used in seal drill with Slurry of 18 ft. Was a packer used? Bentonite Diameter of well bore to bottom of seal in. Were any loose strata cemented off? [] Yes [X] No Depth Was a drive shoe used? [] Yes [X] No Was well gravel packed? [] Yes [X] No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusable water? [] Yes [X] No Type of water? Depth of strata Method of sealing strata off

(10) WATER LEVELS: Static level 11/8 22 ft. below land surface Date 4/7/66 Artesian pressure lbs. per square inch Date

(11) WELL TESTS: Drawdown is amount water level is lowered below static level Was a pump test made? [] Yes [] No If yes, by whom? Yield: 50 gal./min. with 0 ft. drawdown after 1 hrs. 100 " 6 " 2 " 200 " 26 " 7 "

(12) WELL LOG: Diameter of well below casing Depth drilled 58 ft. Depth of completed well 58 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns: MATERIAL, FROM, TO. Rows include Topsoil, Brown loam & clay, grey clay & grit, red sandy clay, gravel & clay, clay brown, gravel & clay, sand & fine gravel, gravel & clay.

Work started 3/26 1966. Completed 4/7/ 1966 Date well drilling machine moved off of well 4/7/ 1966

(13) PUMP: Manufacturer's Name Type: H.P.

Water Well Contractor's Certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Raymond C. Gellatly & Ronald S. Witham (Person, firm or corporation) (Type or print)

Address Box 1, Philomath, Oregon

Drilling Machine Operator's License No. 76 [Signed] Raymond C. Gellatly (Water Well Contractor)

Contractor's License No. 77 Date 4/7/ 1966.