

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

RECEIVED AUG 5 1970

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

STATE ENGINEER, SALEM, OREGON 97310

within 30 days from the date of well completion.

STATE ENGINEER SALEM, OREGON

write above this line)

State Well No. 12/5W-11

State Permit No.

Bent 434

(1) OWNER:

Name Mrs. Oscar Kendell
Address 630 S. W. 4th Street Corvallis, Oregon

(2) TYPE OF WORK (check):

New Well [ ] Deepening [ ] Reconditioning [ ] Abandon [ ]
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary [ ] Driven [ ]
Cable [ ] Jetted [ ]
Dug [ ] Bored [ ]

(4) PROPOSED USE (check):

Domestic [ ] Industrial [ ] Municipal [ ]
Irrigation [ ] Test Well [ ] Other [ ]

CASING INSTALLED:

Threaded [ ] Welded [ ]
0" Diam. from 0 ft. to 50 ft. Gage 250

PERFORATIONS:

Perforated? [ ] Yes [ ] No
Type of perforator used Torch
Size of perforations 1/4 in. by 8 in.
36 perforations from 40 ft. to 49 ft.

(7) SCREENS:

Well screen installed? [ ] Yes [ ] No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? [ ] Yes [ ] No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
Bailer test 18 gal./min. with 20 ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used Cement & Puddled Clay
Well sealed from land surface to 38 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 2 sacks
Number of sacks of bentonite used in well seal sacks
Brand name of bentonite
Number of pounds of bentonite per 100 gallons of water lbs./100 gals.
Was a drive shoe used? [ ] Yes [ ] No Plugs Size: location ft.
Did any strata contain unusable water? [ ] Yes [ ] No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? [ ] Yes [ ] No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Benton Driller's well number
1/4 Section 11 T. 12S R. 5W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 45 ft.
Static level 26 ft. below land surface. Date 6/22/70
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 6
Depth drilled 70 ft. Depth of completed well 70 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

Table with 4 columns: MATERIAL, From, To, SWL. Rows include Topsoil, Yellow Clay, Yellow Sandy Clay, Sandy Gray Clay, Coarse Sand & Gravel, Gray Clay, Blue Clay.

Work started 6-17-70 19 Completed 6-22-70 19
Date well drilling machine moved off of well 6-22-70 19

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Date 6-26-70, 19
(Drilling Machine Operator)

Drilling Machine Operator's License No. 310

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Casey Jones Well Drilling Co Inc
(Person, firm or corporation) (Type or print)

Address R 8 Box 695 Pleasant Hill, Oregon

[Signed] Date
(Water Well Contractor)

Contractor's License No. 103 Date 6-26-70, 19