

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

RECEIVED

WATER WELL REPORT

Bent  
403

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

STATE OF OREGON (Please type or print)

State Well No. 12/4W-30

State Permit No.

(1) OWNER:

Name LEONARD F. GILES  
Address KIAR ISLAND CORVALLIS, OREGON

(2) LOCATION OF WELL:

County Benton Driller's well number  
1/4 1/4 Section 30 T. 125 R. 4W W.M.  
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well [x] Deepening [ ] Reconditioning [ ] Abandon [ ]  
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [ ] Industrial [ ] Municipal [ ]  
Irrigation [x] Test Well [ ] Other [ ]

(5) TYPE OF WELL:

Rotary [ ] Driven [ ]  
Cable [x] Jetted [ ]  
Dug [ ] Bored [ ]

(6) CASING INSTALLED:

Threaded [ ] Welded [x]

6" Diam. from 0 ft. to 32 ft. Gage # 250  
" Diam. from ft. to ft. Gage  
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? [x] Yes [ ] No

Type of perforator used touch  
Size of perforations 3/16 in. by 12 in.  
12 perforations from 23 ft. to 31 ft.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.

(8) SCREENS:

Well screen installed? [ ] Yes [x] No

Manufacturer's Name Model No.  
Slot size Set from ft. to ft.  
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Riddled Bentonite  
Depth of seal 18 ft. Was a packer used? NO  
Diameter of well bore to bottom of seal 9 in.  
Were any loose strata cemented off? [ ] Yes [x] No Depth  
Was a drive shoe used? [ ] Yes [x] No  
Was well gravel packed? [ ] Yes [x] No Size of gravel:  
Gravel placed from ft. to ft.  
Did any strata contain unusable water? [ ] Yes [x] No  
Type of water? depth of strata  
Method of sealing strata off

(10) WATER LEVELS:

Static level 13 ft. below land surface Date 7/23/65  
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? [ ] Yes [x] No If yes, by whom?  
Yield: gal./min. with ft. drawdown after hrs.  
" " " " "

Bailer test 48 gal./min. with 1 ft. drawdown after 1 hrs.  
Artesian flow g.p.m. Date  
Temperature of water Was a chemical analysis made? [ ] Yes [x] No

(12) WELL LOG:

Diameter of well below casing

Depth drilled 32 ft. Depth of completed well 32 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Soil	0	3
CLAY	3	8
GRAVEL, fine w/ CLAY, yellow	8	15
Sand, fine, brown	15	21
GRAVEL, fine + sand	21	32
COURSE		
WATER LAYER		

Work started July 21 1965 Completed July 23 1965

Date well drilling machine moved off of well July 23 1965

(13) PUMP:

Manufacturer's Name Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME L.W. Mutschler Well Drilling (Person, firm or corporation) (Type or print)  
Address 2001 OAK CREEK Rd. Corvallis, Oregon

Drilling Machine Operator's License No. 80

[Signed] Terry W. Mutschler (Water Well Contractor)

Contractor's License No. 237 Date July 23 1965