

**NOTICE TO WATER WELL CONTRACTOR**

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

NOV 7 1967

STATE OF OREGON

(Please type or print)

(Do not write above this line)

STATE ENGINEER SALEM OREGON

*Card sent in on Fred Pointer  
BENT 6301  
812 N 36 Corvallis  
Bent 6301  
10/19/67  
6301  
G-4380*

State Well No. 13/5w-21E

State Permit No.

(1) OWNER: Fred Pointer Pres.  
Name Maddy River Hunt Club  
Address 5th & Harrison Corvallis  
Bob Labhart Sec.

(2) TYPE OF WORK (check):  
New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:  
Rotary  Driven   
Cable  Jetted   
Dug  Bored   
(4) PROPOSED USE (check):  
Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

(5) CASING INSTALLED:  
Threaded  Welded   
8" Diam. from 0 ft. to 38 ft. Gage 25.0  
" Diam. from ft. to ft. Gage  
" Diam. from ft. to ft. Gage

(6) PERFORATIONS:  
Perforated?  Yes  No.  
Type of perforator used GAS TORCH  
Size of perforations 4 in. by 14 in.  
22 perforations from 2.8 ft. to 3.7 ft.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.

(7) SCREENS:  
Well screen installed?  Yes  No  
Manufacturer's Name  
Type Model No.  
Diam. Slot size Set from ft. to ft.  
Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.  
Static level 14 ft. below land surface Date OCT. 20-67  
Artesian pressure lbs. per square inch Date

(9) WELL TESTS:  
Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom?  
id: gal./min. with ft. drawdown after hrs.  
" " " " "  
" " " " "  
Bailer test 45 gal./min. with 4 ft. drawdown after 1 hrs.  
Artesian flow g.p.m. Date  
Temperature of water Was a chemical analysis made?  Yes  No

(10) CONSTRUCTION:  
Well seal—Material used Bentonite  
Depth of seal 18 ft.  
Diameter of well bore to bottom of seal 12 in.  
Were any loose strata cemented off?  Yes  No Depth  
Was a drive shoe used?  Yes  No  
Did any strata contain unusable water?  Yes  No  
Type of water? depth of strata  
Method of sealing strata off  
Was well gravel packed?  Yes  No Size of gravel:  
Gravel placed from ft. to ft.

(11) LOCATION OF WELL:  
County Benton Driller's well number  
1/4 1/4 Section 21 T. 13S R. 5W W.M.  
Bearing and distance from section or subdivision corner

(12) WELL LOG:  
Diameter of well below casing 8  
Depth drilled 40 ft. Depth of completed well 40 ft.  
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
<u>BROWN Top soil</u>	<u>0</u>	<u>3</u>	
<u>GRAY CHAY</u>	<u>3</u>	<u>14</u>	
<u>BROWN SANDY CHAY</u>	<u>14</u>	<u>26</u>	
<u>BROWN SAND &amp; GRAVEL</u>	<u>26</u>	<u>31</u>	
<u>COURSE GRAVEL</u>	<u>31</u>	<u>38</u>	
<u>Blue CHAY</u>	<u>38</u>	<u>40</u>	<u>14</u>

Work started OCT. 19 1967 Completed OCT 20 1967  
Date well drilling machine moved off of well OCT 20 1967

Drilling Machine Operator's Certification:  
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.  
[Signed] Bill Howell Date NOV. 4, 1967  
(Drilling Machine Operator)  
Drilling Machine Operator's License No. 79

Water Well Contractor's Certification:  
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
NAME Howell Well Drilling  
(Person, firm or corporation) (Type or print)  
Address Rt 2 Corvallis Ore  
[Signed] Bill Howell  
(Water Well Contractor)  
Contractor's License No. 5D Date NOV. 4, 1967