

Bent 6343

RECEIVED

RECEIVED

13/5w-36N

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

SEP 9 1965

WATER WELL REPORT

FEB 11 1966

State Well No.

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

STATE ENGINEER
OREGON

STATE OF OREGON
(Please type or print)
63500

STATE ENGINEER
SALEM, OREGON

State Permit No.

(1) OWNER: Crocker Bros., or
Name C. C. Lindseth
Address Rt. 3 Junction City, Ore.

(2) LOCATION OF WELL:
County Benton Driller's well number
1/4 Section 35 T. 13S R. 5W W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check): Domestic Industrial Municipal
Irrigation Test Well Other
(5) TYPE OF WELL: Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED: Threaded Welded
12" Diam. from 0 ft. to 32 ft. Gage 281
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS: Perforated? Yes No
Type of perforator used torch
Size of perforations 1/4 in. by 12 in.
64 perforations from 18 ft. to 32 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS: Well screen installed? Yes No
Manufacturer's Name
Type Model No.
Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:
Well seal—Material used in seal Buddled clay & cement
Depth of seal 18 ft. Was a packer used?
Diameter of well bore to bottom of seal 16 in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? Yes No
Type of water depth of strata
Method of sealing strata off

(10) WATER LEVELS:
Static level 12 ft. below land surface Date 7/29/65
Artesian pressure lbs. per square inch Date

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?

Table with 4 columns: Yield (gal./min. with), ft. drawdown after, hrs. Rows for Bailer test 9000 and Artesian flow.

(12) WELL LOG: Diameter of well below casing 12"
Depth drilled 35 ft. Depth of completed well 35 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with 3 columns: MATERIAL, FROM, TO. Rows for Top soil--brown clay, Sandy clay, Sand & gravel, Blue clay.

Work started 7/26/65 19 Completed 7/29/65 19
Date well drilling machine moved off of well 7/29/65 19

(13) PUMP:
Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME Casey Jones Well Drilling Co.
Address Rt. 2 Box 695, Creswell, Oregon
Drilling Machine Operator's License No. 155
[Signed] Delbert Jones
Contractor's License No. 103 Date 8/6/65