

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

RECEIVED

OCT 11 1965 WATER WELL REPORT

Bank 6635

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion

STATE ENGINEER OF OREGON (Please type or print) SALEM OREGON

G-3836

State Well No. 14/5W-1 B

State Permit No.

(1) OWNER:

Name Horning Bros. Address Rt. 3 Box 588 Corvallis, Oregon

(2) LOCATION OF WELL:

County Benton Driller's well number W 1/4 Section 1 T. 14 S. R. 5 E. W.M. Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well [x] Deepening [] Reconditioning [] Abandon [] Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal [] Irrigation [] Test Well [x] Other [] Rotary [] Driven [] Cable [x] Jetted [] Dug [] Bored []

(5) TYPE OF WELL:

(6) CASING INSTALLED:

10" Diam. from 0 ft. to 31 ft. Gage .250 Threaded [] Welded [x]

(7) PERFORATIONS:

Perforated? [x] Yes [] No Type of perforator used Torch Size of perforations 1/4 in. by 12 in. 30 perforations from 18 ft. to 30 ft.

(8) SCREENS:

Well screen installed? [] Yes [x] No Manufacturer's Name Type Model No. diam. Slot size Set from ft. to ft. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Puddled clay & cement. Depth of seal 18 ft. Was a packer used? Diameter of well bore to bottom of seal 14 in. Were any loose strata cemented off? [] Yes [x] No Depth Was a drive shoe used? [x] Yes [] No Was well gravel packed? [] Yes [x] No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusable water? [] Yes [x] No Type of water? depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level 12 ft. below land surface Date 8/3/65 Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [] Yes [x] No If yes, by whom? Yield: gal./min. with ft. drawdown after hrs. Bailer test 9000 gal./min. with 0 ft. drawdown after 1 hrs. Artesian flow g.p.m. Date Temperature of water Was a chemical analysis made? [] Yes [x] No

(12) WELL LOG:

Diameter of well below casing 10" Depth drilled 32 ft. Depth of completed well 32 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows: Top soil (0-3), Sandy clay (3-8), Sand & gravel (8-32)

Work started 7/31/65 19 Completed 8/3/65 19 Date well drilling machine moved off of well 8/3/65 19

(13) PUMP:

Manufacturer's Name Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Casey Jones Well Drilling Co. (Person, firm or corporation) (Type or print)

Address Rt. 2 Box 695 Creswell, Oregon

Drilling Machine Operator's License No. 155

[Signed] Delbert Jones (Water Well Contractor)

Contractor's License No. 103 Date 8/6/65 19