Bent 6752

847-2106 Monroe

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED MAY 24 1965 STATE ENGINEER SALEM OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)

State Well No. 14/5W-12E

G-4942

State Permit No. G3498

(1) OWNER: Keith

Name Crocker Bros. Farms

Address Rt. 3 Box 617
Junction City, Oregon

(2) LOCATION OF WELL:

County Benton Driller's well number

¼ ¼ Section 12 T. 14S R. 5W W.M.

Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☒ Test Well ☐ Other ☐

(5) TYPE OF WELL:

Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(6) CASING INSTALLED: Threaded ☐ Welded ☒

12" Diam. from 0 ft. to 34 ft. Gage .281
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS: Perforated? ☒ Yes ☐ No

Type of perforator used Mills

Size of perforations 3/8 in. by 12 in.

90 perforations from 18 ft. to 34 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS: Well screen installed? ☐ Yes ☒ No

Manufacturer's Name
Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Puddled clay & cement

Depth of seal 18 ft. Was a packer used?

Diameter of well bore to bottom of seal 16 in.

Were any loose strata cemented off? ☐ Yes ☒ No Depth

Was a drive shoe used? ☒ Yes ☐ No

Was well gravel packed? ☐ Yes ☒ No Size of gravel:

Gravel placed from ft. to ft.

Did any strata contain unusuable water? ☐ Yes ☒ No

Type of water? depth of strata

Method of sealing strata off

(10) WATER LEVELS:

Static level 8½ ft. below land surface Date 3-12-65

Artesian pressure lbs. per square inch Date

(11) WELL TESTS: Drawdown is amount water level is lowered below static level

Was a pump test made? ☐ Yes ☐ No If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "

Bailer test 9000 gal./hr. with 0 ft. drawdown after 1 hrs.

Artesian flow g.p.m. Date

Temperature of water Was a chemical analysis made? ☐ Yes ☒ No

(12) WELL LOG: Diameter of well below casing 12"

Depth drilled 37 ft. Depth of completed well 37 ft.

Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
Brown sandy clay	0	6
Sand & gravel	6	36
Blue clay	36	37

Work started 3-10-65 19 . Completed 3-12-65 19

Date well drilling machine moved off of well 3-15-65 19

(13) PUMP:

Manufacturer's Name

Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Casey Jones Well Drilling Co.
(Person, firm or corporation) (Type or print)

Address Rt. 2 Box 695 Creswell, Oregon

Drilling Machine Operator's License No. 155

[Signed] Delbert A. Jones
(Water Well Contractor)

Contractor's License No. 103 Date 3-15-65, 19

(USE ADDITIONAL SHEETS IF NECESSARY)