

NOTICE TO WATER WELL CONTRACTOR
 The original and first copy
 of this report are to be
 filed with the
 STATE ENGINEER, SALEM, OREGON 97310
 within 30 days from the date
 of well completion.

*Bent
6888*

RECEIVED
 MAY 26 1967
 STATE ENGINEER
 OREGON
 G-4678

WATER WELL REPORT

STATE OF OREGON
 (Please type or print)

State Well No. 14/5W-26
 State Permit No. _____

14/5W-26

(1) OWNER:

Name FE GALLAGHER
 Address 1900 BENTON DR. EUGENE ORE

(2) LOCATION OF WELL:

County BENTON Driller's well number _____
 1/4 Section 26 T. 14S R. 5W W.M.
 Bearing and distance from section or subdivision corner _____

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
 If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
 Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
 Cable Jetted
 Dug Bored

(6) CASING INSTALLED:

Threaded Welded
1.0" Diam. from 0 ft. to 23 ft. Gage 1/2 WALL
 _____" Diam. from _____ ft. to _____ ft. Gage _____
 _____" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No
 Type of perforator used GAS TORCH
 Size of perforations 3/4 in. by 1 1/2 in.
23 perforations from 16 ft. to 22 1/2 ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed? Yes No
 Manufacturer's Name _____ Model No. _____
 Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
 Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Cement & Chaff
 Depth of seal 18 ft. Was a packer used? NO
 Diameter of well bore to bottom of seal 13 in.
 Were any loose strata cemented off? Yes No Depth _____
 Was a drive shoe used? Yes No
 Was well gravel packed? Yes No Size of gravel: _____
 Gravel placed from _____ ft. to _____ ft.
 Did any strata contain unusable water? Yes No
 Type of water? _____ depth of strata _____
 Method of sealing strata off _____

(10) WATER LEVELS:

Static level 9 ft. below land surface Date MAY
 Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
 Was a pump test made? Yes No If yes, by whom?
 Yield: gal./min. with ft. drawdown after hrs.
 " " " "
 " " " "
 Baller test 40 gal./min. with 1/2 ft. drawdown after 1 hrs.
 Artesian flow g.p.m. Date _____
 Temperature of water _____ Was a chemical analysis made? Yes No

(12) WELL LOG:

MATERIAL	FROM	TO
SANDY LOAM	0	6
GRAVEL & SAND	6	15
COURSE GRAVEL & SAND	15	22
PACKED SAND	22	23

Work started MAY 8 1967 Completed MAY 10 1967
 Date well drilling machine moved off of well MAY 10 1967

(13) PUMP:

Manufacturer's Name _____
 Type: _____ H.P. _____

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Howell Well Drilling
 (Person, firm or corporation) (Type or print)

Address Rt 2 Corvallis ORE

Drilling Machine Operator's License No. 79

[Signed] Bill Howell
 (Water Well Contractor)

Contractor's License No. 50 Date MAY, 1967