

RECEIVED
MAY 26 1967

Bent
6889

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the
STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

WATER WELL REPORT ENGINEER

STATE OF OREGON State Well No. 14/5w-26

(Please type or print) G-4078

State Permit No.

14/5w-26
E
F

(1) OWNER:
Name F. E. Gallagher
Address 1900 Beacon Dr. Eugene Ore

(2) LOCATION OF WELL:
County Benton Driller's well number
1/4 Section 26 T 14S R. 5W W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):
Domestic Industrial Municipal Irrigation Test Well Other
(5) TYPE OF WELL:
Rotary Driven Cable Jetted Dug Bored

(6) CASING INSTALLED:
10" Diam. from 0 ft. to 22 ft. Gage 1/2" wall
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:
Perforated? Yes No
Type of perforator used Gas Torch
Size of perforations 3/8 in. by 12 in.
23 perforations from 16 ft. to 21 1/2 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:
Well screen installed? Yes No
Manufacturer's Name
Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:
Well seal—Material used in seal Cement + ch 44
Depth of seal 14 ft. Was a packer used? no
Diameter of well bore to bottom of seal 17 in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:
Static level 9 ft. below land surface Date May-67
Artesian pressure lbs. per square inch Date

(11) WELL TESTS: Drawdown is amount water level is lowered below static level.
Was a pump test made? Yes No If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Ballor test 40 gal./min. with 1/2 ft. drawdown after 1 hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes No

(12) WELL LOG: Diameter of well below casing
Depth drilled 22 ft. Depth of completed well 22 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
SANDY LOAM	0	5
GRAVEL + SAND	5	14
COURSE GRAVEL	14	22

Work started MAY 4 1967 Completed MAY 8 1967
Date well drilling machine moved off of well MAY 8 1967

(13) PUMP:
Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME Havell Well Drilling
(Person, firm or corporation) (Type or print)
Address RT 2 Corvallis Ore
Drilling Machine Operator's License No. 79
[Signed] Bill Sobwell
(Water Well Contractor)
Contractor's License No. 50 Date MAY, 1967