NOTICE TO WATER WELL CONTRACTOR The original and first copy

of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

(Please type or priNTATE ENGINEER
(Do not write above this lifeALEM OREGON Permit No.

(1) OWNER:	(10) LOCATION OF WELL:		
Name JIM KOHL	County BENTON Driller's well nu	mber	
Address Rt 1 Box 475	14 14 Section 33 T. 148	r. 5 w	W.M.
Monroe, Oregon	Bearing and distance from section or subdivision	on corner	
(2) TYPE OF WORK (check):			
New Well g Deepening Reconditioning Abandon			2
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed w	oll	
(3) TYPE OF WELL: (4) PROPOSED USE (check):	The state of the s	*.	
	Depth at which water was first found	125	ft.
Cable	Static level 63 ft. below land s	urface. Date	6/1/13
Dug □ Bored □ Irrigation □ Test Well □ Other □	Artesian pressurelbs. per squar	e inch. Date	
CASING INSTALLED: Threaded Welded	(12) WELL LOG: Diameter of well h		<u></u>
6 "Diam from 0 ft to 20 ft Gage 250			
"Diam. fromft. toft. Gage	Depth drilled 270 ft. Depth of comple		
" Diam. fromft. toft. Gage	Formation: Describe color, texture, grain size a and show thickness and nature of each stratur		
	with at least one entry for each change of format	ion. Report ed	ich change in
PERFORATIONS: Perforated? Yes KNo.	position of Static Water Level and indicate prin	ipal water-be	aring strata.
Type of perforator used	MATERIAL	From To	o swr
Size of perforations in. by in.	top soil	0' 1'	
perforations from ft. to ft.	tan sandy clay	1 7	
perforations from ft. to ft.	blue sandstone-hd	7 12	4
perforations from ft. to ft.	gray claystone-hd	124 12	<u>:9 </u>
	lite gray sandstone-med hd	129 19	<u></u>
(7) SCREENS: Well screen installed? Yes XNo	dark gray sandstone-med hd	191 25	3
Manufacturer's Name	blue to gray sandstone	253 27	0
Type Model No			
Diam. Slot sizeft. toft.	1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1		
Diam. Slot size Set from ft. to ft.			
(8) WELL TESTS: Drawdown is amount water level is			
lowered below static level	-		
Was a pump test made? ☐ Yes ■ No If yes, by whom?			
Yield: gal./min. with ft. drawdown after hrs.		· ·	
" "			
" tested with air: estimate could fluctuate"			
REMER test 75 gal./min. with 207 ft. drawdown after 1 hrs.			
			
	6/6/97	- 6/7/77	
perature of water Depth artesian flow encounteredft.		ed 6/7/73	19
(9) CONSTRUCTION:	Date well drilling machine moved off of well	0/1/15	19
Well seal—Material used cement grout	Drilling Machine Operator's Certification:		to the transfer of the second
Well sealed from land surface to	This well was constructed under my	direct sup	pervision.
Diameter of well bore to bottom of sealin.	Materials used and information reported best knowledge and belief.	above are	rue to my
Diameter of well bore below seal		Date 6/15/	73 . 19
Number of sacks of cement used in well seal	[Signed] Robert W. Classes Date 6/15/73, 19		
Number of sacks of bentonite used in well seal sacks	Drilling Machine Operator's License No.	658	AND ALL DESCRIPTION OF THE PROPERTY OF THE PRO
Brand name of bentonite	W.11 00-4-1-1-0-130		
Number of pounds of bentonite per 100 gallons	Water Well Contractor's Certification:		
of waterlbs./100 gals.	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.		
Was a drive shoe used? Yes No Plugs Size: location ft.	Name CORVALLIS DRILLING CO) INC	
Did any strata contain unusable water? 🔲 Yes 📮 No	Name (Person, firm or corporation)	(Type or	print)
Type of water? depth of strata	Address 3440 sw 3rd; Corvall		n
Method of sealing strata off			
	[Signed]	actor)	
Was well gravel packed? Yes I No Size of gravel:	Contractor's License No. 560 Date 6	<i>t</i>	
Gravel placed from ft. to ft.	Contractor's License No. 200 Date		, 19