Bent
7136

RECEIVED
MAY 17 1967
STATE ENGINEER
SALEM, OREGON

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the
STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

WATER WELL REPORT

STATE OF OREGON
(Please type or print)

State Well No. 14/5w-36M
G-3970
State Permit No.

(1) OWNER:

Name ELDON BROWN
Address RT 3 JUNCTION CITY ORE

(2) LOCATION OF WELL:

County BENTON Driller's well number
¼ ¼ Section 36 T. 14S R. 5W W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☒ Test Well ☐ Other ☐

(5) TYPE OF WELL:

Rotary ☐ Driven ☒
Cable ☐ Jetted ☐
Dug ☐ Bored ☐

(6) CASING INSTALLED:

Threaded ☒ Welded ☐
4 " Diam. from 0 ft. to 25 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? ☒ Yes ☐ No
Type of perforator used Acetylene
Size of perforations 1/4 in. by 4 in.
32 perforations from 20 ft. to 25 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Bentonite
Depth of seal 6 ft. Was a packer used?
Diameter of well bore to bottom of seal 8 in.
Were any loose strata cemented off? ☐ Yes ☒ No Depth
Was a drive shoe used? ☐ Yes ☒ No
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 9 ft. below land surface Date 5/11/67
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? ☒ Yes ☐ No If yes, by whom? Driller
Yield: 250 gal./min. with 11 ft. drawdown after 2 hrs.
" " " "
" " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water 54 Was a chemical analysis made? ☐ Yes ☒ No

(12) WELL LOG:

Diameter of well below casing -
Depth drilled 25 ft. Depth of completed well 25 ft.
Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
Top soil & Brown clay	0	8
packed sand & gravel	8	19
water bearing gravel Course.	19	25

Work started 5/11 1967 Completed 5/11 1967
Date well drilling machine moved off of well 5/11 1967

(13) PUMP:

Manufacturer's Name -
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME O. B. NYE
(Person, firm or corporation) (Type or print)
Address JUNCTION CITY ORE
Drilling Machine Operator's License No. 211
[Signed] O. B. Nye
(Water Well Contractor)
Contractor's License No. 151 Date 5/11, 1967

(USE ADDITIONAL SHEETS IF NECESSARY)