NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

Bent 7269

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

(Do not write above this line)

RECEIVED NOV 29 1976 WATER RESOURCES DEPT SALEM, OREGON

State Well No. 14S/6W-23db

State Permit No. G-7939

(1) OWNER:

Name Al Berdahl

Address 1055 S.E. Marion St. Corvallis, Oregon 97330

(2) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary ☒ Driven ☐
Cable ☐ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):

Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

CASING INSTALLED:

Threaded ☐ Welded ☒

6 " Diam. from 0 ft. to 20 ft. Gage .250

5 " Diam. from 0 ft. to 305 ft. Gage .258

" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated? ☒ Yes ☐ No.

Type of perforator used Torch

Size of perforations 1/4 in. by 5 in.

40 perforations from 265 ft. to 304 ft.

perforations from ft. to ft.

perforations from ft. to ft.

(7) SCREENS:

Well screen installed? ☐ Yes ☒ No

Manufacturer's Name

Type Model No.

Diam. Slot size Set from ft. to ft.

Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? ☐ Yes ☒ No If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.

" " " "

" Tested with air Could Flowrate "

Bailer test 30 gal./min. with 255 ft. drawdown after 4 hrs.

Artesian flow g.p.m.

Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used Cement

Well sealed from land surface to 19 ft.

Diameter of well bore to bottom of seal 10 in.

Diameter of well bore below seal 6 in.

Number of sacks of cement used in well seal 4 sacks

Number of sacks of bentonite used in well seal sacks

Brand name of bentonite

Number of pounds of bentonite per 100 gallons of water lbs./100 gals.

Was a drive shoe used? ☐ Yes ☒ No Plugs Size: location ft.

Did any strata contain unusable water? ☐ Yes ☒ No

Type of water? depth of strata

Method of sealing strata off

Was well gravel packed? ☐ Yes ☒ No Size of gravel:

Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Benton Driller's well number S/125/U

¼ ¼ Section 23 T. 14S R. 6W W.M.

Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 285 ft.

Static level 51 ft. below land surface. Date 11/3/76

Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 6

Depth drilled 305 ft. Depth of completed well 305 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
Topsoil	0	1	
Brown Clay	1	9	
Yellow Clay	9	13	
Gray Sandstone	13	180	
Conglomerate	180	201	
Dark Grey Sandstone	201	305	

Work started 11/2/76 19 Completed 11/5/76 19

Date well drilling machine moved off of well 11/5/76 19

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] (Drilling Machine Operator) Date 11/15, 1976

Drilling Machine Operator's License No. 829

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Corvallis Drilling Co. Inc. (Person, firm or corporation) (Type or print)

Address 3440 SW 3rd St. Corvallis, Oregon 97330

[Signed] Lawrence A Kinney (Water Well Contractor)

Contractor's License No. 560 Date 11/15/76, 19

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119