## RECEIVED

## WATER WELL REPORT STATE OF OREGON

JUN 3 1981

WATER RESOURCES DEPT SALEM, OREGON

Bent State Well No. 145/6W-6 Chandone a 1344 State Permit No.

(1) OWNER:	(10) LOCATION OF WELL:
Name Alpine School District 26C	County Benton Driller's well number
Address Rt.2 Box 200	1/ 1/9:11
City Monroe, Oregon 97456 State	74 Section 25 T. 148 R. 6W W.F.  Tax Lot # 6100 Lot Blk Subdivision
(2) TYPE OF WORK (check):	Address at well location:
New Well □ Deepening □ Reconditioning □ Abandon X	
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.
	Depth at which water was first found
(CIRCUL).	Static level ft. below land surface. Date
Rotary Air Driven Domestic Dindustrial Municipal Katary Mud Dug Driven Driven Driven Domestic Dindustrial Municipal Katary Mud Driven D	Artesian pressure lbs. per square inch. Date
Co X Bored	(12) WELL LOG: Diameter of well below casing 6
(5) CASING INSTALLED: Steel Plastic Threaded Welded	Depth drilled 0 ft. Depth of completed well 0 f  Formation: Describe color, texture, grain size and structure of materials; and shot thickness and nature of each stratum and aquifer penetrated, with at least one entr
"Diam from ft. to ft. Gauge "Diam from ft. to ft. Gauge Gaug	for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.
LINER INSTALLED:	MATERIAL From To SWL
ft. Gauge	From To SWL
(a) DEDUCE A PRODUCT	Existing well was 80 ft.
(6) PERFORATIONS: Perforated? N Yes □ No  Type of perforator used mills knife	the casing was perforated
Size of perforations 3/8 in. by 2 in.	through out and cement
perforations from ft. to ft.	was pumped in from bottom
perforations from	up through trimie.
perforations from	<u> </u>
(7) SCREENS: Well screen installed? ☐ Yes ☐ No Manufacturer's Name	
Type	
Diam. Slot Size Set from ft. to ft.	
Diam. Slot Size Set from ft. to ft.	
(8) WELL TESTS:  Drawdown is amount water level is lowered below static level	
Was a pump test made? ☐ Yes → No If yes, by whom?	
gal/min. with ft. drawdown after hrs.	
" " "	
Air test gal./min. with drill stem at ft. hrs.	
Bailer test gal./min. with ft. drawdown after hrs.	
Artesian flow g.p.m.	
Depth artesian flow encountered ft.	Work started 4/30 1981 Completed 4/30 1981
(9) CONSTRUCTION: Special standards: Yes □ No 🖾	Date well drilling machine moved off of well 4/30 19 81
Well seal—Material usedCement	Drilling Machine Operator's Certification:
Well sealed from land surface totop	This well was constructed under my direct supervision. Materials used
Diameter of well bore to bottom of seal	and information reported above are true to my best knowledge and belief.
Diameter of well bore below sealin.	[Signed]
Number of sacks of cement used in well seal21 sacks How was cement grout placed?Pumpedthrough .trimie	Drilling Machine Operator's License No
	Water Well Contractor's Certification:  This well was drilled under my invital diagram and the
Was pump installed? NO	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Was a drive shoe used? ☐ Yes K No Plugs no. Size: location ft.	Name Corvallis Drilling Co. Inc.
Did any strata contain unusable water? □ Yes , ₩ No	(Person firm or corporation) (Type or print) Address 3440 SW 3rd St. Convallis, Oregon 97330
Type of Water? depth of strata	Audiess July July 200 GOLDATIES, OLEGOII 3(330
Method of sealing strata off	[Signed]
Was well gravel packed? ☐ Yes ☐ XNo Size of gravel;	(Water Well Contractor)  Contractor's License No
Gravel placed from ft to	