

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

RECEIVED
JUL 21 1964
STATE ENGINEER

WATER WELL REPORT
CLAC
 (Please type or print) **G-3655**

State Well No. **5/2-17E**
 State Permit No. _____

(1) OWNER:
 Name **CHAUNCEY BUNKE**
 Address **RT 3 BOX 425**
MOHAWA

(2) LOCATION OF WELL:
 County _____ Driller's well number _____
SW 1/4 NW 1/4 Section 17 T. 53 R. 2E W.M.
 Bearing and distance from section or subdivision corner _____

(3) TYPE OF WORK (check):
 Well Deepening Reconditioning Abandon
 If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check): Domestic Industrial Municipal
 Irrigation Test Well Other

(5) TYPE OF WELL:
 Rotary Driven
 Cable Jetted
 Dug Bored

(6) CASING INSTALLED: Threaded Welded
 6" Diam. from 47' ft. to 17.07' ft. Gage 17.07'
 5" Diam. from 40' ft. to 117' ft. Gage 117'

(7) PERFORATIONS: Perforated? Yes No
 Type of perforator used **TORCH**
 Size of perforations 4 in. by 12 in.
 40 perforations from 97' ft. to 117' ft.
 10 perforations from 47' ft. to 57' ft.

(8) SCREENS: Well screen installed? Yes No
 Manufacturer's Name _____ Model No. _____
 Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
 Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:
 Well seal—Material used in seal **CEMENT**
 Depth of seal **20** ft. Was a packer used? **YES**
 Diameter of well bore to bottom of seal **1.0** in.
 Were any loose strata cemented off? Yes No Depth _____
 Was a drive shoe used? Yes No
 Was well gravel packed? Yes No Size of gravel: _____
 Gravel placed from _____ ft. to _____ ft.
 Did any strata contain unusable water? Yes No
 Type of water? _____ Depth of strata _____
 Method of sealing strata off _____

(10) WATER LEVELS:
 Static level **35** ft. below land surface Date **7/20/64**
 Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
 Was a pump test made? Yes No If yes, by whom?
 Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.
 " " " " " "
 " " " " " "
 Bailer test **32** gal./min. with **20** ft. drawdown after **2** hrs.
 Artesian flow _____ g.p.m. Date _____
 Temperature of water **55** Was a chemical analysis made? Yes No

(12) WELL LOG: Diameter of well below casing **6"**
 Depth drilled **117** ft. Depth of completed well **115** ft.
 Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
CEMENTED GRAVEL	0	32
RED AND BROWN CLAY	32	55
WATER BEARING	55	
STATIC 25' TEMP 55		
BLUE CLAY	55	105
SAND STREAKS IN	105	115
BLUE CLAY WATER		
BEDRING		

Work started **JULY 15 1964** Completed **JULY 20 1964**
 Date well drilling machine moved off of well **JULY 20 1964**

(13) PUMP: Manufacturer's Name **RED A**
 Type: **SUB.** H.P. **2**

Water Well Contractor's Certification:
 This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
 NAME **WILLIAM J. STENNETT**
 (Person, firm or corporation) (Type or print)
 Address **361 WARNER MILNE RD. ORE CITY**
 Drilling Machine Operator's License No. **170-171**
 [Signed] **William J. Stennett**
 (Water Well Contractor)
 Contractor's License No. **38** Date **July 20**, 19**64**