

WATER WELL REPORT
STATE OF OREGON

CLNO
010379

RECEIVED
MAR 14 1983
WATER RESOURCES DEPT.
SALEM, OREGON

State Well No. 55125-21bb
State Permit No.

(1) OWNER:

Name MARY'S FARM
Address 33070 S. Sawtell Road
City Molalla 97038 State Oregon

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL: (4) PROPOSED USE (check):

Rotary Air Driven Domestic Industrial Municipal
Rotary Mud Dug Irrigation Test Well Other
C Bored Thermal: Withdrawal Reinjection

(5) CASING INSTALLED: Steel Plastic
Threaded Welded
6" Diam. from plus 1 ft. to 105 ft. Gauge 250
" Diam. from ft. to ft. Gauge

(6) LINER INSTALLED:
" Diam. from ft. to ft. Gauge

(6) PERFORATIONS: Perforated? Yes No
Type of perforator used saw
Size of perforations 1/8 in. by 7 in.
88 perforations from 66 ft. to 104 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? Yes No
Manufacturer's Name
Type Model No.
Diam. Slot Size Set from ft. to ft.
Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? Driller
80 gal./min. with 15 ft. drawdown after 4 hrs.
Air test gal./min. with drill stem at ft. hrs.
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water 53 Depth artesian flow encountered ft.

(9) CONSTRUCTION: Special standards: Yes No
Well seal—Material used Cement grout
Well sealed from land surface to 26 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 21 sacks
How was cement grout placed? Pumped between 10-inch hole and 6-inch casing
Was pump installed? NO Type HP Depth ft.
Was a drive shoe used? Yes No Plugs Size: location ft.
Did any strata contain unusable water? Yes No
Type of Water? surface depth of strata 3-16 ft.
Method of sealing strata off cement grout
Was well gravel packed? Yes No Size of gravel: 3/8 minus
Gravel placed from 26 ft. to 105 ft.

(10) LOCATION OF WELL:
County Clackamas Driller's well number 4-83
NW 1/4 NW 1/4 Section 21 T.5S R.2E W.M.
Tax Lot # Lot Blk Subdivision
Address at well location: 33070 S. Sawtell Road
Molalla, Oregon 97038

(11) WATER LEVEL: Completed well.
Depth at which water was first found 68 ft.
Static level 47 ft. below land surface. Date 2-28-83
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing
Depth drilled 105 ft. Depth of completed well 105 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Clay-brown	0	3	
Cemented gravel-boulders	3	16	2
Clay-gray	16	68	
Sand-black-coarse	68	83	47
Clay-gray	83	105	

Work started 2-11 1983 Completed 2-28 1983
Date well drilling machine moved off of well 2-28 1983

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Ronald F. McConnell Date 3-11, 1983
(Drilling Machine Operator)
Drilling Machine Operator's License No. 398

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name RONALD F. MCCONNELL dba Steinman Bros
(Person, firm or corporation) (Type or print)
Address 3023 SE Holly Ave., Milwaukie, Or 97222
[Signed] Ronald F. McConnell
(Water Well Contractor)
Contractor's License No. 1 Date 3-11-83, 19.....

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310
within 30 days from the date of well completion. SP*12658-690