NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED MAR 29 1972 STATE ENGINEER SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

CLAC 010550

State Well No. 5/2-31ad
State Permit No.

(1) OWNER:
Name Dewayne Guild
Address Molalla, Oreg

(2) TYPE OF WORK (check):
New Well ☐ Deepening ☒ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☒ Driven ☐
Cable ☐ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED: Threaded ☐ Welded ☒ Liner
6" Diam. from 248 ft. to 270 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS: Perforated? ☒ Yes ☐ No.
Type of perforator used Torch
Size of perforations 1/2 in. by 6 in.
48 perforations from 230 ft. to 268 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☒ Yes ☐ No If yes, by whom? Owner
Yield: 60 gal./min. with 95 ft. drawdown after 2 hrs.
" " " "
" " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used Orig.
Well sealed from land surface to --- ft.
Diameter of well bore to bottom of seal --- in.
Diameter of well bore below seal --- in.
Number of sacks of cement used in well seal --- sacks
Number of sacks of bentonite used in well seal --- sacks
Brand name of bentonite ---
Number of pounds of bentonite per 100 gallons of water --- ? lbs./100 gals.
Was a drive shoe used? ☐ Yes ☐ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Clackamas Driller's well number
S.E. ¼ N.E. ¼ Section 31 T. 5 S. R. 2 E. W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 262 ft.
Static level 145 ft. below land surface. Date 2/17/72
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 8"
Depth drilled 276 ft. Depth of completed well 262 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
Orig Depth, H. basalt		223	
H. basalt grey	223	262	
M. ravelly Claystone green grey W.B.	262	276	

Work started 2/11/72 19 Completed 2/17/72 19
Date well drilling machine moved off of well 2/17/72 19

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] C. L. Stadeli (Drilling Machine Operator) Date 3/2/72, 19
Drilling Machine Operator's License No. 84

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name R. Stadeli & Sons Inc. (Person, firm or corporation) (Type or print)
Address Silverton, Oreg.
[Signed] Paul R. Stadeli (Water Well Contractor)
Contractor's License No. 296 Date 3/2/72, 19

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119