Corrected by WRD staff

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the
WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

RECEIVED MAY 26 1978 WATER RESOURCES DEPT. SALEM, OREGON

CLAC 010597

State Well No. 5S/2E-35
State Permit No. G-9000

(1) OWNER:
Name Richard A. Russo
Address Rt. 1 Box 121 B
Mollalla, Oregon97038

(2) TYPE OF WORK (check):
New Well [X] Deepening [] Reconditioning [] Abandon []
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary [X] Driven []
Cable [] Jetted []
Dug [] Bored []

(4) PROPOSED USE (check):
Domestic [X] Industrial [] Municipal []
Irrigation [X] Test Well [] Other []

CASING INSTALLED:
Threaded [] Welded [X]
6" Diam. from top ft. to 40 ft. Gage
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS:
Perforated? [] Yes [X] No
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:
Well screen installed? [] Yes [X] No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? [] Yes [X] No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
rtest 250 GPM for a period of 6 hours
" " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used Portland Cement
Well sealed from land surface to 40 ft.
Diameter of well bore to bottom of seal 12 in.
Diameter of well bore below seal 8 in.
Number of sacks of cement used in well seal 17 sacks
How was cement grout placed? pumped in

Was a drive shoe used? [X] Yes [] No Plugs Size: location ft.
Did any strata contain unusable water? [] Yes [X] No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? [] Yes [X] No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Clackamas Driller's well number 2128
¼ ¼ Section 34 T 5S R. 2E W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 195 ft.
Static level 132 ft. below land surface. Date 3/4/78
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:
Diameter of well below casing 8
Depth drilled 475 ft. Depth of completed well 475 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Topsoil	0	2	
Brown Clay	2	28	
Hard Shale	28	35	
Black Basalt	35	195	
Water Bearing Basalt(6gpm	195	200	133
Black Basalt	200	271	
Hard Blue Shale	271	448	
Unstable Shale (may cave in) water bearing	448	469	
Green Granite	469	475	

Work started 2/21/78 19 Completed 3/4/78 19
Date well drilling machine moved off of well 3/4/78 19

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Dallas L Beers (Drilling Machine Operator) Date 3/6/78, 19
Drilling Machine Operator's License No. 752

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Willamette Drilling Co. (Person, firm or corporation) (Type or print)
Address 1450 Barnick Rd. NE Salem, Oregon
[Signed] Dallas L Beers (Water Well Contractor)
Contractor's License No. 561 Date 3/6/78, 19

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119