

NC

CLAC

RECEIVED

010703

5/3E-6 F

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

JAN 12 1968 WATER WELL REPORT

State Well No. 5/3E-6 F

STATE ENGINEER, SALEM, OREGON STATE ENGINEER (Please type or print)

State Permit No.

(1) OWNER:

Name R. A. M. P. Adams Address

(2) LOCATION OF WELL:

County Clackamas Driller's well number SE 1/4 NW 1/4 Section 6 T. 5 S R. 3 E W.M. Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well [x] Deepening [] Reconditioning [] Abandon []

(4) PROPOSED USE (check):

Domestic [x] Industrial [] Municipal [] Irrigation [] Test Well [] Other []

(5) TYPE OF WELL:

Rotary [] Driven [] Cable [x] Jetted [] Dug [] Bored []

(6) CASING INSTALLED:

8" Diam. from 0 ft. to 9.50 ft. Gage 2.50 6.1 ft. Gage 11

(7) PERFORATIONS:

Perforated? [] Yes [x] No Type of perforator used Size of perforations in. by in.

(8) SCREENS:

Well screen installed? [] Yes [x] No Manufacturer's Name Model No. Slot size Set from ft. to ft. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal GROUT Depth of seal 6.0 ft. Was a packer used? NO Diameter of well bore to bottom of seal 11 in. Were any loose strata cemented off? [] Yes [x] No Depth Was a drive shoe used? [x] Yes [] No Was well gravel packed? [] Yes [x] No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusable water? [] Yes [x] No Type of water? depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level 38 ft. below land surface Date Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [x] Yes [] No If yes, by whom? Driller Yield: 50 gal./min. with 18 ft. drawdown after 18 hrs. Bailer test gal./min. with ft. drawdown after hrs. Artesian flow g.p.m. Date Temperature of water 52 Was a chemical analysis made? [] Yes [x] No

(12) WELL LOG:

Diameter of well below casing 8" Depth drilled 116 ft. Depth of completed well 116 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows include soil (sandy red), gravel med., clay (green), clay (gray), clay (blue), dark shale (hard), blue shale (water), dark shale (hard & broken (water)).

Work started 19 Completed 11-19 1965 Date well drilling machine moved off of well 19

(13) PUMP:

Manufacturer's Name Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. NAME Jew Beck Well Drilling (Person, firm or corporation) (Type or print) Address RT 3 BOX 45 Drilling Machine Operator's License No. H 37 [Signed] John W Beck (Water Well Contractor) Contractor's License No. 449 Date 19