

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

WATER WELL REPORT

STATE OF OREGON (Please type or print)

CLAC 01 1985

State Well No. 3/1-3/ State Permit No.

STATE ENGINEER SALEM, OREGON

(1) OWNER:

Name Bert Garre Address 12746, N.E. Shaver, Portland Ore.

(2) LOCATION OF WELL:

County Clack. Driller's well number 31 T. 3S R. 1E W.M. Bearing and distance from section or subdivision corner

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level. Was a pump test made? Yes No If yes, by whom J. T. Miller Yield: 300 gal./min. with 43 ft. drawdown after hrs.

(12) WELL LOG:

Diameter of well below casing 105 Depth drilled 105 ft. Depth of completed well 105 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows include surface, clay-yellow, conglomerate, clay, gravel, clay-blue, sand, water, black, coarse sand, gravel, water.

TYPE OF WORK (check):

New Well Deepening Reconditioning Abandonment

(4) PROPOSED USE (check):

Domestic Industrial Municipal Rotary Cable Dug Irrigation Test Well Other

(5) TYPE OF WELL:

Driven Jettted Bored

(6) CASING INSTALLED:

Threaded Welded 8" Diam. from 0 ft. to 105 ft. Gage

(7) PERFORATIONS:

Perforated? Yes No toarch- millknife Size of perforations in. by in. 1/4x3 zig, zag perforations from 95 ft. to 104 ft.

(8) SCREENS:

Well screen installed Yes No Manufacturer's Name Model No. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal cement Depth of seal ft. Was a packer used? Diameter of well bore to bottom of seal in. Were any loose strata cemented off? Yes No Depth

(10) WATER LEVELS:

Static level 7 ft. below land surface Date Artesian pressure lbs. per square inch Date

(13) PUMP:

Rapidayton Manufacturer's Name 6T75A125 Sub. H.P. 7-1/2

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME J. T. Miller (Person, firm or corporation) (Type or print)

Address Box 175, Aurora, Ore.

Drilling Machine Operator's License No. 121

[Signed] J. T. Miller (Water Well Contractor)

Contractor's License No. 7 Date 4-8th 1963