

**WATER WELL REPORT
STATE OF OREGON**

CLAC
011999

RECEIVED

DEC 29 1981

**WATER RESOURCES DEPT
SALEM, OREGON**

State Well No. 3S/1E-32

State Permit No. _____

(1) OWNER:

Name Canby Grove Conference Center
Address 7501 Knights Bridge Rd.
City Canby State Oregon

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Air Driven
Rotary Mud Dug
 Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other
Thermal: Withdrawal ReInjection

(5) CASING INSTALLED:

Steel Plastic
Threaded Welded
8" Diam. from 0 ft. to 65 ft. Gauge .250

LINER INSTALLED:

(6) PERFORATIONS:

Perforated? Yes No

Type of perforator used _____
Size of perforations _____ in. by _____ in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name Johnson
Type Stainless Model No. _____
Diam. 8" Slot Size 25 Set from 65 ft. to 75 ft.
Diam. _____ Slot Size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? D & A Pump
" 125 gal./min. with 49 ft. drawdown after 1 hrs.
Air test _____ gal./min. with drill stem at _____ ft. _____ hrs.
Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m.
Temperature of water _____ Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:

Special standards: Yes No

Well seal—Material used Cement w/5% Bentonite
Well sealed from land surface to _____ 35 ft.
Diameter of well bore to bottom of seal _____ 12 in.
Diameter of well bore below seal _____ 8 in.
Number of sacks of cement used in well seal _____ 20 sacks
How was cement grout placed? Pumped
Was pump installed? Yes Type Sub HP 15 Depth 68 ft.
Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of Water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(10) LOCATION OF WELL:

County Clackamas Driller's well number 3581
Tax Lot # _____ Lot 32 Blk _____ Subdivision _____
Address at well location: 7501 Knights Bridge Rd.,
Canby, Oregon

(11) WATER LEVEL: Completed well.

Depth at which water was first found _____ 20 ft.
Static level _____ 16 ft. below land surface. Date 10-22-81
Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing _____ 0
Depth drilled _____ 75 ft. Depth of completed well _____ 75 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Sand, Soil	0	4	
Clay Brown & Gravel Large	4	20	
Sand Grey Coarse	20	28	
Clay Grey	28	37	
Sand Grey Fine	37	53	
Sand Grey Med.	53	63	
Sand Brown Med.	63	65	
Sand Grey Med. to Coarse	65	67	
Sand Brown Med.	67	69	
Sand Grey Med.	69	72	
Sand Grey Med., some Gravel			16'
	72	75	16'

Work started 10-19 1981 Completed 10-22 1981
Date well drilling machine moved off of well 10-22 1981

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Mami D. Skyles Date 12-28 1981
(Drilling Machine Operator)
Drilling Machine Operator's License No. 224

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Skyles Drilling, Inc.
(Person, firm or corporation) (Type or print)
Address 1169 Molalla Ave., Oregon City, OR.
[Signed] Mami D. Skyles
(Water Well Contractor)
Contractor's License No. 553 Date 12-28 1981

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date of well completion.

SP*12658-690