

RECEIVED  
MAR 12 1962

STATE ENGINEER WATER WELL REPORT  
CLACKAMAS COUNTY, OREGON STATE OF OREGON

CLAC

3/1-35

File Original and  
First Copy with the  
STATE ENGINEER,  
SALEM, OREGON

State Well No. ....

State Permit No. ....

(1) OWNER:

Name Emil Kraft  
Address Canby, Ore.

(2) LOCATION OF WELL:

County Clackamas Owner's number, if any—  
1/4 Section 35 T. 3S R. 1E W.M.  
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon   
Abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal  Rotary  Driven   
Irrigation  Test Well  Other  Cable  Jetted   
Dug  Bored

(5) TYPE OF WELL:

(6) CASING INSTALLED:

Threaded  Welded   
10" Diam. from 0 ft. to 236 ft. Gage std.  
6" Diam. from 221 ft. to 257 ft. Gage 250  
" Diam. from " ft. to " ft. Gage

(7) PERFORATIONS:

Perforated?  Yes  No  
Type of perforator used Torch  
SIZE of perforations 1/8 in. by 12 in.  
66 perforations from 227 ft. to 253 ft.  
perforations from " ft. to " ft.  
perforations from " ft. to " ft.  
perforations from " ft. to " ft.  
perforations from " ft. to " ft.

(8) SCREENS:

Well screen installed  Yes  No  
Manufacturer's Name  
Type Model No.  
" Slot size Set from " ft. to " ft.  
" Slot size Set from " ft. to " ft.

(9) CONSTRUCTION:

Was well gravel packed?  Yes  No Size of gravel: 3/8  
Gravel placed from 227 ft. to 253 ft.  
Was a surface seal provided?  Yes  No To what depth? 30 ft.  
Material used in seal— drill cuttings  
Did any strata contain unusable water?  Yes  No  
Type of water? Depth of strata  
Method of sealing strata off

(10) WATER LEVELS:

Static level 74 ft. below land surface Date 1/30/62  
Artesian pressure lbs. per square inch Date

Log Accepted by:

[Signed] Emil Kraft Date Feb. 7, 1962  
(Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by Pump Pipe & Power  
Yield: 340 gal./min. with 131 ft. drawdown after 1 1/2 hrs.  
" 280 " 111 " 3/4 "  
" 210 " 88 " 3/4 "  
Bailer test gal./min. with ft. drawdown after hrs.  
Artesian flow g.p.m. Date  
Temperature of water 52 Was a chemical analysis made?  Yes  No

(12) WELL LOG:

Diameter of well 10 inches.  
Depth drilled 257 ft. Depth of completed well 257 ft.  
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Brown sandy clay	0	22
Cement gravel & boulders	22	44.7
Yellow clay silt & gravel	44.7	55
Yellow sand & silt	55	68
Cemented gravel	68	94
Blue clay	94	175
Grey clay	175	198
Blue clay	198	207
Gray sandy clay	207	216
Gray silt	216	243
Gray packed sand (water)	243	255
Gray clay	255	257

Work started 12/7/61 19 . Completed 1/30/62 19

(13) PUMP:

Manufacturer's Name  
Type: H.P.

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Steinman Bros.  
(Person, firm, or corporation) (Type or print)

Address 15112 S.E. McLoughlin, Milwaukie Ore.

Driller's well number 962

[Signed] Steinman Bros.  
(Well Driller)

License No. 1 Date 2/7/62, 19