

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

CLAC

012453

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

(Do not write above this line)

RECEIVED
DEC 26 1967
STATE ENGINEER
SALEM OREGON

State Well No. 4/1-23 B

State Permit No. G-8641

(1) OWNER:

Name DR. EDMUND E. DAVIES
Address 152 N. E. Wait Canby, Oregon

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded
10" Diam. from 0 ft. to 420 ft. Gage 2.279
6" Diam. from 260 ft. to 410 ft. Gage 10
" Diam. from " ft. to " ft. Gage "

PERFORATIONS:

Perforated? Yes No.

Type of perforator used _____
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name ROSCO MOSS
Type FULL FLO Model No. _____
Diam. 6 Slot size 1/16 Set from 410 ft. to 450 ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WATER LEVEL: Completed well.

Static level 90 ft. below land surface Date 12-18-67
Man pressure _____ lbs. per square inch Date _____

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? Driller
Yield: 300 gal./min. with 260 ft. drawdown after 3 hrs.
200 " 170 " 5 "
" " " " "
Baller test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date _____

Temperature of water 54 Was a chemical analysis made? Yes No

(10) CONSTRUCTION:

Well seal—Material used Bentonite
Depth of seal 150 ft.
Diameter of well bore to bottom of seal 14 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No size of gravel: 1/8x1/4
Gravel placed from 400 ft. to 450 ft.

(11) LOCATION OF WELL:

County Clackamas Driller's well number 1967-35
NW cor. NE 1/4 Section 23 T. 4S R. 1E W.M.
Bearing and distance from section or subdivision corner _____

(12) WELL LOG:

Diameter of well below casing 10

Depth drilled 555 ft. Depth of completed well 450 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
top soil	0	4	
clay, brown	4	28	
clay, blue	28	45	
gravel, Med	45	74	
conglomerate	74	105	
clay, brown	105	112	
clay, blue	112	152	
clay, grey	152	224	
sand, coarse black	224	228	
clay, blue	228	249	
sand, coarsa, black	249	253	70
clay, grey	253	413	
413 clay, blue, sticky	413	450	
Sand, medium black with fine gravel	450	502	
clay, blue	502	555	

Work started July 2 1967 Completed Sep 26 1967

Date well drilling machine moved off of well Sep 26 1967

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Maxwell D. Skyles Date Dec. 18, 1967
(Drilling Machine Operator)

Drilling Machine Operator's License No. 224

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Skyles Drilling & Supply
(Person, firm or corporation) (Type or print)

Address Gladstone, Oregon

[Signed] George J. Skyles
(Water Well Contractor)

Contractor's License No 58 Date 12-18, 1967