

NOTICE TO WATER WELL CONTRACTOR

The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM 10, OREGON
within 30 days from the date
of well completion.

WATER WELL REPORT
RECEIVED
STATE OF OREGON
(Please type or print)
SEP 9 1963

CLACK
12458

State Well No. 91-23P

G2728

State Permit No.

(1) OWNER:

STATE ENGINEER

Name Orlin R. Bevier,
Address Rt. 3, Box 134, Canby, Ore.

(2) LOCATION OF WELL:

County Clack. Driller's well number
1/4 Section 23 T. 4S R. 1E W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☒ Test Well ☐ Other ☐

(5) TYPE OF WELL:

Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(6) CASING INSTALLED:

10" Diam. from 0 ft. to 130 ft. Gage 1/4
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? ☒ Yes ☐ No
Type of perforator used mill knife
Size of perforations zig zag in by in.
50 perforations from 70 ft. to 77 ft.
60 perforations from 89 ft. to 94 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed ☐ Yes ☐ No
Manufacturer's Name
Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal cemented
Depth of seal 20 ft. Was a packer used?
Diameter of well bore to bottom of seal in.
Were any loose strata cemented off? ☐ Yes ☐ No Depth
Was a drive shoe used? ☐ Yes ☐ No
Was well gravel packed? ☒ Yes ☐ No Size of gravel: pea
Gravel placed from top ft. to bottom ft.
Did any strata contain unusable water? ☐ Yes ☐ No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 32 ft. below land surface Date
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? ☒ Yes ☐ No If yes, by whom J. T. Miller

Yield: 250 gal./min. with 70 ft. drawdown after 8 hrs.

" " " "

Baller test gal./min. with ft. drawdown after hrs.

Artesian flow g.p.m. Date

Temperature of water Was a chemical analysis made? ☐ Yes ☐ No

(12) WELL LOG:

Diameter of well below casing 10
Depth drilled 130 ft. Depth of completed well 130 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
surface	0	2
sandy clay, yellow	2	19
surface sand and water, red	19	23
soft sandy clay, gray	23	47
clay, gravel, and cemented	47	51
sand and gravel, water	51	52
clay, gray	52	70
coarse sand, small gravel, water	70	77
clay, gray	77	89
sand, gravel, black, water	89	94
soft clay, black	94	110
broken clay, sand, water	110	118
clay, blue	118	120
sand, small gravel, black, water	120	130

Work started 8-13- 19 63 Completed 9-3- 19 63

Date well drilling machine moved off of well 19

(13) PUMP: 1-1 HP. Sub., 1-10 HP. Sub,

Manufacturer's Name Rapidayton,
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME J. T. Miller (Type or print)

Address Box 175, Aurora, Ore.

Drilling Machine Operator's License No. 191

[Signed] J. T. Miller (Water Well Contractor)

Contractor's License No. 7 Date 9-5- 19 63

(USE ADDITIONAL SHEETS IF NECESSARY)