

(1) OWNER: STATE ENGINEER
Name Harold Jensen
Address Rt 3 Bx 142 Canby, Oregon.

(10) WELL TESTS:
Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. draw down after hrs.
" " " " "
" " " " "
Artesian flow g.p.m.
Shut-in pressure lbs. per square inch.
Ballor test 36 g.p.m. 300 at 73 ft. 300
Temperature of water Was a chemical analysis made? Yes No
Was electric log made of well? Yes No

(2) LOCATION OF WELL:
County Clackamas Owner's number, if any--
R. F. D. or Street No. Rt 3 Bx 142, Canby, Oregon.
Bearing and distance from section or subdivision corner
Well in N.E. corner of Sec. 23
T 4 S. R 1 E.
"Macksburg Store"

(11) WELL LOG:
Diameter of well, 6 inches.
Total depth 117 ft. Depth of completed well 117 ft.

(3) TYPE OF WORK (check):
New well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):
Domestic Industrial Municipal
Irrigation Test Well Other
(5) EQUIPMENT:
Rotary
Cable
Dug Well

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.
ft. to ft.
0 " 18 " yellow clay.
18 " 22 " brown muckey sand.
22 " 25 " blue clay.
25 " 39 " cement gravel, no water.
39 " 47 " yellow silty clay.
47 " 48 " gravel, no water.
48 " 57 " brown clay.
57 " 71 " cement gravel, 6 GPM at 73'
71 " 85 " yellow clay.
85 " 93 " grey clay.
93 " 105 " yellow sandy clay. all
water & sand shut off by 6" pipe at 94'
105 " 112 " brown hard pan, water.
112 " 117 " brown clay & gravel/ water.

(6) CASING INSTALLED:
Threaded Welded
FROM ft. to ft. Diam. Gage or Wall Diameter of Bore from ft. to ft.
" " " " " " " " " " "
" 0 " 94 " 6 " .250 " " " " " "
" 90 " 117 " 5 " .250- liner " " " " " "
" " " " " " " " " " "
Type and size of shoe or well ring. Size of gravel:
Describe joint

(7) PERFORATIONS:
Type of perforator used
SIZE of perforations in., length, by in.
FROM ft. to ft. perf per foot No. of rows
" " none " " " " " " " "
" " " " " " " " " " "
" " " " " " " " " " "
" " " " " " " " " " "

SCREENS:
Give Manufacturer's Name, Model No. and Size
none

(8) CONSTRUCTION:
Was a surface sanitary seal provided? Yes No To what depth ft.
Were any strata sealed against pollution? Yes No
If yes, note depth of strata
FROM ft. to ft.
" All shut "off at bottom of shoe
METHOD OF SEALING filled in around pipe also.

(9) WATER LEVELS:
Depth at which water was first found 78-6 G.P.M. ft.
Standing ~~level~~ ~~perforating~~ ft.
Standing ~~level~~ ~~perforating~~ Static 41 ft. ft.
Log Accepted by:
[Signed] _____ Dated Apr. 19 56
Owner

5" perforated liner from 90' to 117'
at 108' hole made 16 G.P.M.
" 112' " " 21 G.P.M.
" 117' " bailing at 36 GPM could
get water down to 73' and it held there
at 36 G.P.M.
" " "
" " "
" " "
" " "

Ground elevation at well site abt. 300 feet above mean sea level
Work started Apr. 19 56 Completed Apr. 19 56
Well Driller's Statement:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME Steinman Bros. (Person, firm, or corporation) (Typed or printed)
Address 8332, S. E. 16th Ave. Portland, Oregon.
Driller's well number 856
[Signed] E. Steinman (Well Driller)
License No. 1 Dated _____, 19 _____