

CLAG  
12500

NC

RECEIVED

4/1-24

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

STATE OF OREGON (Please type or print)

State Well No. G-4654

State Permit No.

(1) OWNER:

Name Rufus Krosberger & Joe Vrores  
Address Rt 3 Box 184 Canby Ore.

(2) LOCATION OF WELL:

County Clackamas Driller's well number  
NE 1/4 SW 1/4 Section 24 T. 45 S. R. 1 E W.M.  
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon   
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal  Irrigation  Test Well  Other   
(5) TYPE OF WELL:  
Rotary  Driven  Cable  Jetted  Dug  Bored

(6) CASING INSTALLED:

10" Diam. from 0 ft. to 434 ft. Gage 1250  
" Diam. from ft. to ft. Gage  
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated?  Yes  No  
Type of perforator used Steir 4 way  
Size of perforations 1/4 in. by 2 in.  
200 perforations from 170 ft. to 180 ft.  
300 perforations from 230 ft. to 245 ft.  
200 perforations from 365 ft. to 375 ft.  
200 perforations from 390 ft. to 395 ft.

(8) SCREENS:

Well screen installed?  Yes  No  
Manufacturer's Name  
Model No.  
Diam. Slot size Set from ft. to ft.  
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Grout  
Depth of seal 40 ft. Was a packer used? 140  
Diameter of well bore to bottom of seal 16 in.  
Were any loose strata cemented off?  Yes  No Depth  
Was a drive shoe used?  Yes  No  
Was well gravel packed?  Yes  No Size of gravel:  
Gravel placed from ft. to ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? depth of strata  
Method of sealing strata off

(10) WATER LEVELS:

Static level 17 ft. below land surface Date 8-11  
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom? Miller  
Yield: 500 gal./min. with 73 ft. drawdown after 4 hrs.  
" " " "  
" " " "  
" " " "  
Bailer test gal./min. with ft. drawdown after hrs.  
Artesian flow g.p.m. Date  
Temperature of water 53° Was a chemical analysis made?  Yes  No

(12) WELL LOG:

Diameter of well below casing 10  
Depth drilled 446 ft. Depth of completed well 446 ft.  
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top Soil	0	6
Dark Brown silt & clay	6	38
Cement gravel (Brown)	38	105
Clay (Green)	105	111
Clay Gray	111	170
Clay & sand (water)	170	179
Clay Dark Blue	179	204
Clay Gray	204	224
Clay (Redish brown)	204	231
sand (course) water	231	245
Clay (Gray)	245	285
Clay (Dark Blue)	285	315
Clay (Green)	315	322
Clay (Dark)	322	365
Clay & fine gravel	365	374
Clay (Dark Blue)	374	389
Clay Stone (Crumbles) water	389	396
Clay (Gray)	396	430
Clay & Dark silt	430	434
Sand (water)	434	446

Work started 5-12 1966 Completed 8-11 1966  
Date well drilling machine moved off of well 8-11 1966

(13) PUMP:

Manufacturer's Name  
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME John W Beck well drilling  
(Person, firm or corporation) (Type or print)

Address Rt 3 Box 45 Canby Ore.

Drilling Machine Operator's License No. 437

[Signed] John W Beck  
(Water Well Contractor)

Contractor's License No. 449 Date 8-12 1966