WATER WELL REPORT STATE OF OREGON

RECEIVED State Well No. 45/12-27aa

	JUN4	1982		•
			State Permit No.	
MIER	RESOU	RCFS	NEDT	

/,	WATER	RESOURCES	State Permit No. DEPT			
SALEM, OREGON						
	(10) T	OCATION OF	A WESTERN W.			

	1
1) OWNER:	(10) LOCATION OF WELL:
Name Gordan Wanner	County Clack amas Driller's well number 209
address 28211 S. Dryland Rd.	NE 4 NE 4 Section 27 T. 4S R. 1E W.M.
State On.	Tax Lot # Lot Blk Subdivision
2) TYPE OF WORK (check):	Address at well location: 28211 S. DryLand Rd.
	Carby, Or.
New Well Deepening □ Reconditioning □ Abandon □	(11) WATER LEVEL: Completed well.
	Depth at which water was first found 39 ft.
3) TYPE OF WELL: (4) PROPOSED USE (check):	Static level 23 ft. below land surface. Date 5/14/
totary Air 💢 Driven 🗆 Domestic 🖸 Industrial 🗎 Municipal 🖂 Mud 🗇 Dug 🖂 Irrigation 🕱 Test Well 🗎 Other	Artesian pressure lbs. per square inch. Date
Bored Thermal: Withdrawal Reinjection	(12) WELL LOG: Diameter of well below casing
5) CASING INSTALLED: Steel 🔀 Plastic 📮	Depth drilled 227 ft. Depth of completed well 227 ft.
Threaded Welded	Formation: Describe color, texture, grain size and structure of materials; and show
8 "Diam from 0 ft to 137 ft Gauge .250	thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level
" Diam. from ft. to ft. Gauge	and indicate principal water-bearing strata.
LINER INSTALLED:	MATERIAL From To SWL
OD "Diam from 127 ft. to 227 ft. Gauge .188	Top soil 0 2
	Clay, brown 2 23
(6) PERFORATIONS: Perforated? XYes \(\sigma \) No Type of perforator used \(\tilde{I} \) Onch	*Clay, sand, brown, fine 23 39
Size of perforations $1/4$ — in. by 8 in.	*Sand, black, fine 39 48
157 163	*Gravel, compact 48 64
9. perforations from 12.1 ft. to 19.6 ft. 6 perforations from 172 ft. to 178 ft.	Sard, brown, Line 64 66
perforations from 185 ft. to 188 ft.	Clay, sand, brown, Line 66 70
21 215 226	Clay, sand, blue, black, fr. 70 91
(7) SCREENS: Well screen installed? Yes X No	Gravel, compact 91 109
Manufacturer's Name	Gravel, clay, brown, med. 109 134
Type Model No	Clay, blue 134 137
Diam. Slot Size Set from ft. to ft.	*Sandstone, black, fract. 137 139
Diam. Slot Size Set from ft. to ft.	Clay, sand, blue, black, fr. 139 157
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	*Sandstone, black, fract. 157 162
a pump test made? X Yes D No If yes, by whom? Driller	Clay, blue 162 173 *Sandstone, black, fract. 173 178
Yield: 250 gal/min. with 39 ft. drawdown after 2 hrs.	Clay, blue 178 185
Il gar/illin. with 57 it. diawdown arter 2 ins.	
Air test gal./min. with drill stem at ft. hrs.	Sandstone, black, fract. 185 188 Clay, blue 188 215
Bailer test gal./min. with ft. drawdown after hrs.	*Sandstore. black. Lract. 215 226
sian flow g.p.m.	Clay. blue 220 227
Temperature of water Depth artesian flow encountered ft.	Work started 4/30 19 82 Completed 5/14 1982
(9) CONSTRUCTION: Special standards: Yes □ No 🛣	Date well drilling machine moved off of well 5/15 1982
Well seal—Material used Cement	Drilling Machine Operator's Certification:
Well sealed from land surface to	This well was constructed under my direct supervision. Materials used
Diameter of well bore to bottom of sealin.	and information reported above are type to my best knowledge and belief.
Diameter of well bore below seal	[Signed] Down Kern Date 5/1519 82
Number of sacks of cement used in well seal	(Drilling Machine Operator)
How was cement grout placed? Pressure grouted from	Drilling Machine Operator's License No
9 ft. to land surface.	Water Well Contractor's Certification:
	This well was drilled under my jurisdiction and this report is true to
Was pump installed?	the best of my knowledge and belief.
Was a drive shoe used? X Yes ☐ No Plugs Size: location ft.	Name B&G Drilling (Type or print)
Did any strata contain unusable water? 🔲 Yes 🗶 No	Address 10030 S. Macksburg Rd. Carby, Or.
Type of Water? depth of strata	
Method of sealing strata off	[Signed] Duttout Wanning (Water Well Contractor)
Was well gravel packed? ☐ Yes X No Size of gravel:	Contractor's License No. 637 Date 5/15 , 1982

Gravel placed from ft. to ft.