

AUG 27 1987

WATER RESOURCES DEPT.
SALEM, OREGON

Owner's Well Number:

(9) LOCATION OF WELL by legal description:

County Clackamas Latitude _____ ' _____ " Longitude _____ ' _____ "
Township 4 _____ or S, Range 1 _____ E or ~~XX~~ WM.
Section 28 _____ NE $\frac{1}{4}$ SE $\frac{1}{4}$ _____
Tax Lot _____ Lot _____ Block _____ Subdivision _____

Street Address of Well (or nearest address) 8804 S. Hainz Rd., Canby, OR. 97013

(10) STATIC WATER LEVEL:

45 ft. below land surface. Date _____
Artesian pressure _____ lb. per square inch. Date _____

(11) WELL LOG:

Ground elevation _____

Depth of Completed Well 165 ft.

Special Standards date of approval

How was seal placed? Method ☐ A ☐ B ☒ C ☐ D ☐ E
☐ Other _____

Backfill placed from _____ ft. to _____ ft. ____ Material

Gravel placed from _____ ft. to _____ ft. Size of gravel _____

	Diameter	From	To	Gauge	Steel	Plastic	Welded	Threaded
Casing:	6" <u> </u>	+1 <u> </u>	149 <u> </u>	.250 <u> </u>	☒	☐	☒	☐
	<u> </u>	<u> </u>	<u> </u>	<u> </u>	☐	☐	☐	☐
	<u> </u>	<u> </u>	<u> </u>	<u> </u>	☐	☐	☐	☐
	<u> </u>	<u> </u>	<u> </u>	<u> </u>	☐	☐	☐	☐
	<u> </u>	<u> </u>	<u> </u>	<u> </u>	☐	☐	☐	☐
Liner:	<u> </u>	<u> </u>	<u> </u>	<u> </u>	☐	☐	☐	☐
	<u> </u>	<u> </u>	<u> </u>	<u> </u>	☐	☐	☐	☐

Final location of shoe(s) 149

(7) PERFORATIONS/SCREENS:

☐ Perforations

Method

Screens

Type Telescoping Material Stainless[illegible]

(8) WELL TESTS: Minimum testing time is 1 hour

☐ Pump

☐ Bailer Air☐ Flowing Artesian

Yield gal/min

Pumping level

Drill stem at

Time

100

140

1 hr

Temperature of water _____ Depth Artesian Flow Found _____

Was a water analysis done? ☐ Yes By whom

Did any strata contain water not suitable for intended use? ☐ Too little

☐ Salty ☐ Muddy ☐ Odor ☐ Colored ☐ Other

Depth of strata:

(unbonded) Water Well Constructor Certification:

I constructed this well in compliance with Oregon well construction standards. Materials used and information reported above are true to my best knowledge and belief.

Signed _____ Date _____

(bonded) Water Well Constructor Certification:

I accept responsibility for construction of this well and its compliance with all Oregon water well standards. This report is true to the best of my knowledge and belief.

Signed David Donnelly Date 8-24-87

Company Donnelly Drilling Co. Co. Job No. _____