NOTICE TO WATER WELL CONTRACTOR

The original and first copy
of this report are to be WAY 10

MAY 19 196 WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON 97310 ENGINEER OF OREGON within 30 days from the date of the ENGINEER (Please type or print) of well completion.

Gl	AC
119	582
, , 6	State Well No. 411-22
	State Permit No.

(I) OWNER:	(11) WELL TESTS: Drawdown is amount lowered below static	water lev evel	el is
Name Homer Knopp	Was a pump test made?★ Yes ☐ No If yes, by who		ller
Address Rte 2 Box 330	Yield: gal./min. with 57 ft. drawdo		
Canby, Oregon	" 500 " 57 "		6 "
(2) LOCATION OF WELL:	" 300 " 25 "	7	7 "
(C) a alcamus	Bailer test gal./min. with ft. drawd	lown after	hrs.
of the swell family	Artesian flow g.p.m. Date		
	Temperature of water Was a chemical analysis	made?	Yes 🗑 No
Bearing and distance from section or subdivision corner	(10) TIVELT T.O.C.		
	- ( -		
	Depth drilled 165 ft. Depth of completed w		165 ft.
	Formation: Describe by color, character, size of materi show thickness of aquifers and the kind and nature of stratum penetrated, with at least one entry for each	al and stri the mater	icture, and ial in each
	MATERIAL	FROM	TO
(3) TYPE OF WORK (check):	Soil	+	-
Well 🗶 Deepening 🗌 Reconditioning 🗍 Abandon 🗍		0	5
Ir abandonment, describe material and procedure in Item 12.	Brown sandy clay	3	27
//\ PROPOSED TISE // I I \	Blue sandy clay	27	44
(4) PROPOSED USE (check): (5) TYPE OF WELL:	Brown sandy clay	44	58
Domestic   Industrial   Municipal   Rotary   Driven	Brown clay	58	71
Irrigation ♣ Test Well □ Other □ Cable ♣ Jetted □ Dug □ Bored □	Brown sand	71	75_
(C) CACTAYO TAYOMAY TATO	Broken coarse sand & small	<del>  75</del>	82
(6) CASING INSTALLED: Threaded  Welded	gravel		<u>-</u>
0 ft. to0 ft. to165 ft. Gage14"	Blue sandy clay	82	94
	Black sand	94	108
"Diam. from ft. to ft. Gage	Gravel (good)	108	115
(7) PERFORATIONS: Perforated? ♣ Yes □ No	Broken sand, some gravel	115	120
Type of perforator used Millknife	Good gravel	120	125
-/-	Broken gravel and sand	125	129_
Size of perforations 3/8 in. by 3 in.  120 perforations from 120 ft. to 125 ft.	Blue sandy clay	129	145
•	Sticky blue clay	145	160
perforations from ft. to ft.	Sandy clay	160	165_
perforations from			
perforations from ft. to ft.		<del>                                     </del>	
perforations from ft. to ft.		-	
(8) SCREENS: Well screen installed? ☐ Yes ☑ No			
Manufacturer's Name		<del>                                     </del>	
Model No.		لــــــــــــــــــــــــــــــــــــــ	
Diam Slot size Set from ft. to ft.	Worth start of Mary 6		<del></del>
Diam. Slot size Set from ft. to ft.		ay 13	<u> 19 6</u> 5
(9) CONSTRUCTION:	Date well drilling machine moved off of well		19
	(13) PUMP:		
Well seal—Material used in seal Puddled Mud	Manufacturer's Name		
Depth of seal 20 ft. Was a packer used? 20	Type: H.P.		
Diameter of well bore to bottom of sealin.		.4.4	
Were any loose strata cemented off? Tyes 🖪 No Depth	Water Well Contractor's Certification:		
Was a drive shoe used? ☐ Yes 🏿 No	This well was drilled under my jurisdiction	and this	renort-ia
Was well gravel packed? Tyes X No E Size of gravel:	true to the best of my knowledge and belief.		report is
Gravel placed from ft. to ft.	NAME John Trumon Willan		
Did any strata contain unusable water? 🔲 Yes 🕞 No		pe or print)	
Type of water? depth of strata	Address P O Box 42 Hubbard, Ox	egon	
Method of sealing strata off		_	
(10) WATER LEVELS:	Drilling Machine Operator's License No.	26	
	[Signed] John J. Miller		
Static level 38 ft. below land surface Date 5/13/66	(Water Well Contractor)		
Artesian pressure lbs. per square inch Date	Contractor's License No277 Date May 1	.6	10 66
(IISE ADDITIONAL ST		. 24	, 19