

RECEIVED

CLAC

012649

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON, within 30 days from the date of well completion.

FEB 3 1967 WATER WELL REPORT
STATE OF OREGON (Please type or print)

State Well No. 4/1-29 G
State Permit No. G-3823

(1) OWNER:
Name ELI LILLY & COMPANY SIP 46206
Address P.O. BOX 814 INDIANAPOLIS, INDIANA
DR. CHAMBERLAIN 14819 S.E. PRIMROSE

(2) LOCATION OF WELL: MILWAUKIE, OREGON
County CLACKAMAS Driller's well number II94
1/4 1/4 Section 29 T. 4S R. 1E W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):
New Well [X] Deepening [] Reconditioning [] Abandon []
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):
Domestic [] Industrial [] Municipal [] Irrigation [X] Test Well [] Other []
(5) TYPE OF WELL:
Rotary [] Cable [X] Dug [] Driven [] Jetted [] Bored []

(6) CASING INSTALLED:
Threaded [] Welded [X]
8" Diam. from TOP ft. to I45 ft. Gage 250

(7) PERFORATIONS:
Perforated? [] Yes [X] No
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.

(8) SCREENS:
Well screen installed? [] Yes [X] No
Manufacturer's Name
Model No.
Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:
Well seal—Material used in seal CEMENT & PUDDLE CLAY
Depth of seal 20 ft. Was a packer used?
Diameter of well bore to bottom of seal 10 in.
Were any loose strata cemented off? [] Yes [X] No Depth
Was a drive shoe used? [X] Yes [] No
Was well gravel packed? [] Yes [X] No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? [] Yes [] No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:
Static level 45 ft. below land surface Date I/I9/67
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? [X] Yes [] No If yes, by whom? DRILLER
Yield: 30 gal./min. with 100ft. drawdown after 6 hrs.
Ballor test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? [] Yes [] No

(12) WELL LOG:
Diameter of well below casing 8
Depth drilled I59 ft. Depth of completed well I50 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns: MATERIAL, FROM, TO. Rows include TOP SOIL, YELLOW CLAY, CEMENT GRAVEL & SMALL BOULDERS, STICKY GRAY SHALE, BROWN SHALE, BROWN SAND & SOME SOME SHALE, BLUE SHALE SOFT, BROWN SHALE, BROWN SHALE & SAND, FINE BROWN SAND, BROWN SHALE, BROWN SAND & SOME MUD, BROWN SHALE, BLUE SHALE, BLACK SAND, BLACK PEAT, BLUE SHALE CRUMBLY.

Work started DEC 29 1966 Completed JAN 19 1967
Date well drilling machine moved off of well JAN 19 1967

(13) PUMP:
Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME WILLAMETTE DRILLING CO.
Address RT. 2 BOX 276 SALEM, OREGON
Drilling Machine Operator's License No. 74
[Signed] Emil O. Beev (Water Well Contractor)
Contractor's License No. 2 Date JAN 19 1966