

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report
are to be filed with the

WATER WELL REPORT

CLAC
012864

WATER RESOURCES DEPARTMENT
SALEM, OREGON 97310
within 30 days from the date
of well completion.

RECEIVED

STATE OF OREGON
(Please type or print)

State Well No. 45/E-2
State Permit No. G-9576

NOV 10 1980

(Do not write above this line)

(1) OWNER: WATER RESOURCES DEPT
SALEM, OREGON

Name Craig Zielinski
Address 10290 S Township Rd.
Canby, Oregon 97013

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
 Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
22" Diam. from 0 ft. to 79 ft. Gage $\frac{1}{4}$ "
12" Diam. from 2+ ft. to 242 ft. Gage $\frac{1}{4}$ "
" Diam. from " ft. to " ft. Gage "

(6) PERFORATIONS:

Perforated? Yes No.

Type of perforator used Pre perforated pipe

Size of perforations 3/16 in. by 3 in. 95
120 perforations from 90 ft. to 130 ft.
480 perforations from 110 ft. to 130 ft.
480 perforations from 140 ft. to 160 ft.
720 perforations from 200 ft. to 230 ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? driller
Yield: 550 gal./min. with 140 ft. drawdown after 6 hrs.
" 700 " " 200 " " 6 "

Artesian flow _____ g.p.m.
Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.

Temperature of water _____ Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:

Well seal—Material used Cement
Well sealed from land surface to 79 ft.
Diameter of well bore to bottom of seal 28 in.
Diameter of well bore below seal 22 in.
Number of sacks of cement used in well seal 84 sacks
How was cement grout placed? pumped

Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.

Did any strata contain unusable water? Yes No

Type of water? _____ depth of strata _____

Method of sealing strata off _____

Was well gravel packed? Yes No Size of gravel: 3/4

Gravel placed from 75 ft. to 243 ft.

(10) LOCATION OF WELL:

County Clackamas Driller's well number _____
 $\frac{1}{4}$ $\frac{1}{4}$ Section 2 T. 4S R. 1E W.M.
Bearing and distance from section or subdivision corner _____

(11) WATER LEVEL: Completed well.

Depth at which water was first found 90 ft.
Static level 56 ft. below land surface. Date 10/29/80
Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing _____

Depth drilled 243 ft. Depth of completed well 243 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Soil	0	3	
Brown clay	3	45	
Large gravel & boulders	45	108	
Sand & gravel	108	116	
Gray clay	116	119	
Black sand & gravel	119	130	
Gray clay	130	137	
Black sand & gravel	137	141	
Green clay	141	150	
Brown sand (coarse)	150	153	
Green clay	153	156	
Brown gravel	156	159	
Green sandy clay	159	187	
Gray clay	187	197	
Black sand & gravel	197	204	
Gray clay	204	209	
Brown sand & gravel	209	236	
Gray clay	236	243	

Work started Aug 29 1980 Completed Oct 29 1980

Date well drilling machine moved off of well Oct 29 1980

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] John T. Miller Date Nov. 8, 1980
(Drilling Machine Operator)

Drilling Machine Operator's License No. 26

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name John T. Miller
(Person, firm or corporation) (Type or print)

Address 1780 Tomlin Woodburn, Oregon

[Signed] John T. Miller
(Water Well Contractor)

Contractor's License No. 277 Date Nov. 8, 1980