RECEIVED
JAN 31 1972
STATE ENGINEER
SALEM, OREGON

NC

CLAC
012944

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON

State Well No. 4/1 -6

Clackamas

State Permit No. .....

(1) OWNER:
Name Harold Culp,
Address Rt.3, Box287 Canby, Oregon.

(2) LOCATION OF WELL:
County ..... Owner's number, if any—
¼ ¼ Section T. R. W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):
New Well ☐ X Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):
Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☐ X Test Well ☐ Other ☐

(5) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☐ X Jetted ☐
Dug ☐ Bored ☐

(6) CASING INSTALLED: Threaded ☐ Welded ☐ X
12" Diam. from 0 ft. to 111 ft. Gage .....
..." Diam. from ..... ft. to ..... ft. Gage .....
..." Diam. from ..... ft. to ..... ft. Gage .....

(7) PERFORATIONS: Perforated? ☐ X Yes ☐ No
Type of perforator used
SIZE of perforations in. by in.
80 perforations from 103 ft. to 109 ft.
..... perforations from ..... ft. to ..... ft.
..... perforations from ..... ft. to ..... ft.
..... perforations from ..... ft. to ..... ft.
..... perforations from ..... ft. to ..... ft.

(8) SCREENS: Well screen installed ☐ Yes ☐ No
Manufacturer's Name .....
Type ..... Model No. .....
Diam. ..... Slot size ..... Set from ..... ft. to ..... ft.
Diam. ..... Slot size ..... Set from ..... ft. to ..... ft.

(9) CONSTRUCTION:
Was well gravel packed? ☐ Yes ☐ No Size of gravel: .....
Gravel placed from ..... ft. to ..... ft.
Was a surface seal provided? ☐ Yes ☐ No To what depth? ..... ft.
Material used in seal— X cement
Did any strata contain unusable water? ☐ Yes ☐ No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:
Static level 3 1/2 ft. below land surface Date
Artesian pressure lbs. per square inch Date

Log Accepted by:
[Signed] ..... (Owner) Date ....., 19.....

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? X ☐ Yes ☐ No If yes, by whom? J. T. Miller
Yield: 300 gal./min. with 22 ft. drawdown after hrs.
" 400 " 37 " "
" 500 " 49 " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? ☐ Yes ☐ No

(12) WELL LOG: Diameter of well 12 inches.
Depth drilled 111 ft. Depth of completed well 140 ft.
Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
surface	0	3
coarse clay and gravel	3	8
broken clay gravel, sand	8	23
clay	23	26
broken clay gravel	26	48
black sand	48	49
clay	49	90
sand, water	90	96
sand and gravel, med. water	96	111
clay	111	130
sand, clay, gravel broken, water	130	140

Work started 6-24 1961 Completed 7-3rd 1961

(13) PUMP:
Manufacturer's Name .....
Type: ..... H.P. .....

Well Driller's Statement:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME J. T. Miller, (Person, firm, or corporation) (Type or print)
Address Box 175 Aurora, Ore.
Driller's well number .....
[Signed] J T Miller (Well Driller)
License No. 7 Date 7-3rd, 1961

(USE ADDITIONAL SHEETS IF NECESSARY)