

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

CLACK
012980
G7001

RECEIVED
STATE OF OREGON WATER WELL REPORT
OCT 8 1974 State Well No. 4511E-7ca
(Please type or print) STATE ENGINEER State Permit No.
SALEM, OREGON
(Do not write above this line)

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

(1) OWNER:

Name WEYERHAEUSER CO
Address 505 N. PEARL ST.
CENTRALIA WASH. 98531

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
16" Diam. from 0 ft. to 102 ft. Gage 312
12" Diam. from 71.5 ft. to 103 ft. Gage 250
12" Diam. from 125 ft. to 131 ft. Gage 330

(6) PERFORATIONS:

Perforated? Yes No.

Type of perforator used

Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name VOP JOHNSON
Type STAINLESS STEEL Model No.
Diam. 12 Slot size 60 Set from 103 ft. to 125 ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? STRASSER

Yield: 300 gal./min. with 42 ft. drawdown after 7 hrs.

Bailer test gal./min. with ft. drawdown after hrs.

Artesian flow g.p.m.

Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used CEMENT GROUT

Well sealed from land surface to 20 ft.

Diameter of well bore to bottom of seal 20 in.

Diameter of well bore below seal 16 in.

Number of sacks of cement used in well seal 20 sacks

Number of sacks of bentonite used in well seal sacks

Brand name of bentonite

Number of pounds of bentonite per 100 gallons of water lbs./100 gals.

Was a drive shoe used? Yes No Plug Size: location ft.

Did any strata contain unusable water? Yes No

Type of water? depth of strata

Method of sealing strata off

Was well gravel packed? Yes No Size of gravel: 1/4 MINUS

Gravel placed from 102 ft. to 131 ft.

(10) LOCATION OF WELL:

County CLACK Driller's well number
NE 1/4 SW 1/4 Section 7 T. 45 R. 1E W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 86 ft.
Static level 56 ft. below land surface. Date 9/19/74
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing
Depth drilled 140 ft. Depth of completed well 131 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
TOP SOIL	0	1	
SILTY BROWN SAND	1	72	
SAND AND GRAVEL	72	86	
SAND, GRAVEL AND CLAY	86	93	
BLUE CLAY	93	101	
SAND AND GRAVEL	101	106	
COARSE SAND, FINE GRAVEL	106	128	
SILTY CLAY	128	137	
BLUE CLAY	137	140	

Work started AUG 29 1974 Completed SEPT 24 1974

Date well drilling machine moved off of well SEPT 25 1974

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Dan Johnson Date OCT 7, 1974
(Drilling Machine Operator)

Drilling Machine Operator's License No. 57

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name R.J. STRASSER DRILLING CO
(Person, firm or corporation) (Type or print)

Address 810 S. SUNSET LAKE PORTLAND ORE.

[Signed] Robert J. Strasser
(Water Well Contractor)

Contractor's License No. 10 Date OCT 7, 1974