

STATE OF OREGON  
**WATER WELL REPORT**  
 (as required by ORS 537.765)

**CLAC**  
 013009

AUG 27 1987

491E-82a

WATER RESOURCES DEPT.  
 SALEM, OREGON

**(1) OWNER:** Owner's Well Number: \_\_\_\_\_  
 Name SID MILES  
 Address 7285 S. LOWE ELDER RD  
 City CANBY State OR Zip 97013

**(2) TYPE OF WORK:**  
 New Well  Deepen  Recondition  Abandon

**(3) DRILL METHOD:**  
 Rotary Air  Rotary Mud  Cable  Other

**(4) PROPOSED USE:**  
 Domestic  Community  Industrial  Irrigation  
 Thermal  Injection  Other

**(5) BORE HOLE CONSTRUCTION:**  
 Depth of Completed Well 158 ft.  
 Special Standards date of approval \_\_\_\_\_

HOLE			SEAL		Amount sacks or pounds
Diameter	From	To	Material	To	
12	1	20	BENTONITE 1	20	10
8	20	155			

How was seal placed? Method  A  B  C  D  E  
 Other GRANULAR BENTONITE METHOD

Backfill placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Material \_\_\_\_\_  
 Gravel placed from 144 ft. to 158 ft. Size of gravel 1/4 MINUS

**(6) CASING/LINER:**

Casing/Liner	Diameter	From	To	Gauge	Material			
					Steel	Plastic	Welded	Threaded
Casing:	8	0	145	250	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Liner:	7"	140	148	.188	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
	7"	153	158	.188	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Final location of shoe(s) 145'

**(7) PERFORATIONS/SCREENS:**

Perforations Method \_\_\_\_\_  
 Screens Type WELL STRAINER CORP. Material STAINLESS

From	To	Slot size	Number	Tele/pipe size	Casing	Liner
148	153	30		8	<input type="checkbox"/>	<input type="checkbox"/>

**(8) WELL TESTS: Minimum testing time is 1 hour**

Pump  Bailer  Air  Flowing Artesian

Yield gal/min	Pumping level	Drill stem at	Time
200		105'	1/2 hr
180		105'	1 hr
160		105'	2 hr

Temperature of water \_\_\_\_\_ Depth Artesian Flow Found \_\_\_\_\_  
 Was a water analysis done?  Yes By whom \_\_\_\_\_  
 Did any strata contain water not suitable for intended use?  Too little  
 Salty  Muddy  Odor  Colored  Other \_\_\_\_\_  
 Depth of strata: \_\_\_\_\_

**(9) LOCATION OF WELL by legal description:**  
 County CLATSOP Latitude \_\_\_\_\_ Longitude \_\_\_\_\_  
 Township 4S or S, Range 1 E or W, WM.  
 Section 8 NE 1/4 SE 1/4  
 Tax Lot \_\_\_\_\_ Lot \_\_\_\_\_ Block \_\_\_\_\_ Subdivision \_\_\_\_\_  
 Street Address of Well (or nearest address) SAMIE

**(10) STATIC WATER LEVEL:**  
28' ft. below land surface. Date AUG 5, 1987  
 Artesian pressure \_\_\_\_\_ lb. per square inch. Date \_\_\_\_\_

**(11) WELL LOG:** Ground elevation \_\_\_\_\_

Material	From	To	WB?	SWL
TOPSOIL SANDY	1	3		
PEAT	3	8		
CLAY GREY	8	15		
CEMENTED GRAVEL & COBBLES	15	53		
CLAY GREY	53	58		
CLAY BLUE GREEN	58	73		
CLAY GREEN SAND STREAKS	73	78	✓	
CLAY GREY	78	85		
GREEN CLAY SAND LAYERS	85	95	✓	
GREEN CLAY	95	110		
CLAY GREEN MED. SAND LAYERS	110	116	✓	
GREY CLAY TURNING SILTY	116	145		
SAND BLACK	145	158	✓	
CLAY BLUE	158	182		
SAND BLACK	182	185	✓	

Date started July 28 Completed AUG 5, 1987

**(unbonded) Water Well Constructor Certification:**  
 I constructed this well in compliance with Oregon well construction standards. Materials used and information reported above are true to my best knowledge and belief.

Signed \_\_\_\_\_ Date \_\_\_\_\_

**(bonded) Water Well Constructor Certification:**  
 I accept responsibility for construction of this well and its compliance with all Oregon water well standards. This report is true to the best of my knowledge and belief.

Signed Richard J. Beck Date AUG 5, 1987  
 Company BECK WELL DRILLING Co. Job No. \_\_\_\_\_