RECEIVED
JUN 1 1962
STATE ENGINEER
SALEM, OREGON

CLAC
013075

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

WATER WELL REPORT
STATE OF OREGON
(Please type or print)

State Well No. 4/1-10

State Permit No.

(1) OWNER:
Name Glen Herman
Address Rte 3 Box 178
Canby, Oregon

(2) LOCATION OF WELL:
County Clackamas Driller's well number
¼ ¼ Section 10 T. 4S R. 1E W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):
Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☒ Test Well ☐ Other ☐

(5) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(6) CASING INSTALLED:
Threaded ☐ Welded ☒
8 " Diam. from 0 ft. to 57 ft. Gage
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:
Perforated? ☒ Yes ☐ No
Type of perforator used Millknife
Size of perforations 3/8 in. by 2 in.
48 perforations from 31 ft. to 34 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:
Well screen installed ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:
Well seal—Material used in seal Bentonite Mud
Depth of seal 20 ft. Was a packer used? no
Diameter of well bore to bottom of seal 12 in.
Were any loose strata cemented off? ☐ Yes ☒ No Depth
Was a drive shoe used? ☒ Yes ☐ No
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:
Static level 5 ft. below land surface Date 6/5/62
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? ☒ Yes ☐ No If yes, by whom? driller
Yield: 200 gal./min. with 31 ft. drawdown after 8 hrs.
" " " "
" " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? ☐ Yes ☒ No

(12) WELL LOG:
Diameter of well below casing
Depth drilled 57 ft. Depth of completed well 57 ft.
Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
Surface	0	6
Cement gravel	6	35
Brown sand	35	52
Blue clay	52	57

Work started May 31 1962. Completed June 5 1962
Date well drilling machine moved off of well June 5 1962

(13) PUMP:
Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME John Truman Miller
(Person, firm or corporation) (Type or print)
Address P O Box 42 Hubbard, Oregon

Drilling Machine Operator's License No. 277
[Signed] John T. Miller
(Water Well Contractor)
Contractor's License No. 277 Date June 6, 1962

(USE ADDITIONAL SHEETS IF NECESSARY)