NOTICE TO WATER WELL CONTRACTOR The original and first copy of this report are to be filed with the	REPORT CLAC OREGON 013132 State Well No	45/	1E-1	3 Ca
STATE OF O Within 30 days from the date of well completion.	or print) ve this line)			
(1) OWNER:	(10) LOCATION OF WELL:			
	County Clackamas Driller's well number 15-74			
Name ROWATO D. DUCCHEL	NE 14 SW 14 Section 13 T. 4S R. 1E W.M.			
AddressRt. 2 Box 226	74			
Canby, Oregon 97013	Bearing and distance from section or subdivision corner			
(2) TYPE OF WORK (check):	194			
New Well 【XX Deepening ☐ Reconditioning ☐ Abandon ☐				
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.			
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 9 ft.			
Rotary XX Driven Domestic Industrial Municipal	Static level 5 ft. below land surface. Date 3-9-74			3-9-74
Cable Jetted	Artesian pressure lbs. per square inch. Date			
Dug Bored I Irrigation XX Test Well Other	Artesian pressure			
CASING INSTALLED: Threaded Welded XX	(12) WELL LOG: Diameter of well b	elow car	ing	8
8	176			66 ft.
" Diam. from ft. to ft. Gage				
" Diam. from ft. Gage	Formation: Describe color, texture, grain size and show thickness and nature of each strature	m and a	gulfer pe	netrated,
Diam. 110111	with at least one entry for each change of format	tion. Rep	ort eacn o	enange in
PERFORATIONS: Perforated? Tyes TX.	position of Static Water Level and indicate prin	cipai wa	ter-veum	ty strutu.
Type of perforator used	MATERIAL	From	То	SWL
The state of the s	Topsoil	0	5	
Size of periorations	Lggravel, sand, clay	5	9	
perforations fromft. toft.	Lg. gravel.sm boulders	9	14	
perforations fromft, toft	Small gravel and sand	14	24	
perforations from ft. to ft.	Small gravel, sand, and			
(7) SCREENS: Well screen installed? Yes XX No	yellow clay	24	55	
Manufacturer's Name	Blue clay	55	72	
Type	Med. gravel and sand	72	83	
Diam. Slot size Set from ft. to ft.	Waterbearing 60GPM			
Diam. Slot size Set from ft. to ft.	Grey clay stone	83	87	
	Med. Sandstone	87	99	
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	Grey clay	99	104	
Was a pump test made? ▼ ses □ No If yes, by whom? driller	Greyclay with layers			
	of small gravel & sand			
Yield: 350 gal./min. with 125 ft. drawdown after 1 hrs.	Brown, waterbearing	104	126	
The state of the s	Soft grey clay	126	132	
II	Meduim sandstone	132	136	_5
Bailer test gal./min. with ft. drawdown after hrs.		<u> </u>	<u> </u>	
Artesian flow g.p.m.		<u> </u>	<u>i</u>	<u> </u>
Imperature of water Depth artesian flow encountered ft.	Work started 3-4-74 19 Complet	ed 2	5-9-71	19
	Date well drilling machine moved off of well	7	5-9-71	4 19
(9) CONSTRUCTION:	The state of the s			
Well seal-Mcementa Cement and Bentonite	Drilling Machine Operator's Certification This well was constructed under my	: direc	t sune	rvision.
Well sealed from land surface to 18 ft.	Materials used and information reported	above	are tru	e to my
Diameter of well bore to bottom of seal in.	best knowledge and belief.	. /		
Diameter of well bore below seal in.	[Signed] Liffine South	Date	3 1.	1., 197.4
Number of sacks of cement used in well seal sacks	Drilling Machine Operator's License No.	Ę	71	
Number of sacks of bentonite used in well seal sacks	Drining Wachine Operator's License 140.		*. [
Brand name of bentonite Mud Gel	Water Well Contractor's Certification:			
Number of pounds of bentonite per 100 gallons	This well was drilled under my jurisdiction and this report is			
of water lbs./100 gals.	true to the best of my knowledge and belief.			
Was a drive shoe used? XXes \(\sum_{No} \) Plugs Size: location ft.	the control of the co			
Did any strata contain unusable water? Yes	Name Skyles Drilling and Supply (Person, firm or corporation) (Type or print)			
Type of water? depth of strata	Address 1169 Molalla Avenue			
Method of sealing strata off	[Signed] Same A Hand			
Was well gravel packed? ☐ Yes ☐ Size of gravel:	[Signed] (Water Well Con	ractor)		
was well graver packeur 1es	Contractor's License No. 553 Date	3-1	1	, 1974.
Gravel placed from	1			GD+45050