

RECEIVED

CLAC 013135

45/1E-14ba

STATE OF OREGON WATER WELL REPORT (as required by ORS 537.765)

JAN 29 1987

WATER RESOURCES DEPT SALEM OREGON 292

(1) OWNER:

Name Pat Richardson Address 10301 S. Kraxberger Rd. City Carby State Or. Zip 97013

(2) TYPE OF WORK:

[X] New Well [] Deepen [] Recondition [] Abandon

(3) DRILL METHOD:

[X] Rotary Air [] Rotary Mud [] Cable [] Other

(4) PROPOSED USE:

[X] Domestic [] Community [] Industrial [] Irrigation [] Thermal [] Injection [] Other

(5) BORE HOLE CONSTRUCTION:

Depth of Completed Well 155 ft. Special Standards date of approval

Table with columns: HOLE Diameter, SEAL Material, Amount sacks or pounds. Row 1: 10" 0 to 19' cement, 0 to 19', 20 sacks

How was seal placed? Method [] A [] B [X] C [] D [] E [] Other

Backfill placed from ft. to ft. Material Gravel placed from ft. to ft. Size of gravel

(6) CASING/LINER:

Table with columns: Diameter, From, To, Gauge, Steel, Plastic, Welded, Threaded. Rows for Casing and Liner.

Final location of shoe(s) 140'

PERFORATIONS/SCREENS:

Table with columns: From, To, Slot size, Number, Diameter, Tele/pipe size, Casing, Liner. Includes perforation details.

(8) WELL TESTS: Minimum testing time is 1 hour

Table with columns: Yield gal/min, Pumping level, Drill stem at, Time 1/2 hr. Includes test results.

Temperature of water 54 Depth Artesian Flow Found Was a water analysis done? [] Yes [] No

(9) LOCATION OF WELL by legal description:

County Clack, Latitude Township 4S N or S, Range 1E E or W, WM. Section 14 NE 1/4 NW 1/4 Tax Lot Street Address of Well (or nearest address) 10301 S. Kraxberger Carby, Or.

(10) STATIC WATER LEVEL:

74 ft. below land surface. Date 1/9/87 Artesian pressure lb. per square inch. Date

(11) WELL LOG:

Table with columns: Material, From, To, WB?, SWL. Lists well log materials like Top soil, Clay, sand, brown, fine, etc.

Date started 12/27/86 Completed 1/9/87

(unbonded) Water Well Constructor Certification:

I constructed this well in compliance with Oregon well construction standards. Materials used and information reported above are true to my best knowledge and belief.

Signed Date

(bonded) Water Well Constructor Certification:

I accept responsibility for construction of this well and its compliance with all Oregon water well standards. This report is true to the best of my knowledge and belief.

Signed George J. Wainwright Date 1/9/87 Company B & G Drilling Co. Job No. 292