NOTICE TO WATER WELL CONTRACTOR: The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED JUL 27 1971 STATE ENGINEER SALEM OR.

WATER WELL REPORT

STATE OF OREGON (Please type or print) (Do not write above this line)

CLAC 013185

State Well No. 4/1-15a

State Permit No. G-3897

(1) OWNER:

Name Constantine Etengless

Address R.F.D. 1 Box 348A Canby Oregon

(2) TYPE OF WORK (check):

New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary ☐ Driven ☐
Cable ☑ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):

Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☑ Test Well ☐ Other ☐

CASING INSTALLED:

Threaded ☐ Welded ☑

8 " Diam. from 0 ft. to 110 ft. Gage .250

" Diam. from ft. to ft. Gage

" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated? ☑ Yes ☐ No.

Type of perforator used Mills

Size of perforations 3/8 in. by 2½ in.

64 perforations from 60 ft. to 67 ft.
72 perforations from 80 ft. to 87 ft.
80 perforations from 90 ft. to 100 ft.

(7) SCREENS:

Well screen installed? ☐ Yes ☑ No

Manufacturer's Name

Type Model No.

Diam. Slot size Set from ft. to ft.

Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? ☐ Yes ☑ No If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.

" " " "

" " " "

Bailer test 60 gal./min. with 30 ft. drawdown after 1 hrs.

Artesian flow g.p.m.

Temperature of water 54° Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used Puddle Clay

Well sealed from land surface to 35 ft.

Diameter of well bore to bottom of seal 12 in.

Diameter of well bore below seal 8 in.

Number of sacks of cement used in well seal sacks

Number of sacks of bentonite used in well seal sacks

Brand name of bentonite

Number of pounds of bentonite per 100 gallons of water lbs./100 gals.

Was a drive shoe used? ☑ Yes ☐ No Plugs Size: location ft.

Did any strata contain unusable water? ☐ Yes ☑ No

Type of water? depth of strata

Method of sealing strata off

Was well gravel packed? ☐ Yes ☑ No Size of gravel:

Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Clackamas Driller's well number

¼ ¼ Section 15 T. 4S R. 1E W.M.

Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 63 ft.

Static level 60 ft. below land surface. Date 7/25/71

Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 8

Depth drilled 115 ft. Depth of completed well 115 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
Top Soil	0	2	
Br. Clay	2	20	
Br. Sand	20	25	
Cement Sand	25	115	

Work started 7-15 19 71 Completed 7/25 19 71

Date well drilling machine moved off of well 7/25 19 71

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] J. F. Terrell (Drilling Machine Operator) Date 7/25, 1971

Drilling Machine Operator's License No. 179

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name J. F. Terrell Well Drilling (Person, firm or corporation) (Type or print)

Address 8425 Wheatland Rd. N. Salem Ore.

[Signed] J. F. Terrell (Water Well Contractor)

Contractor's License No. 460 Date 7/25, 1971

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119