NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED APR 24 1972 STATE ENGINEER SALEM OR.

WATER WELL REPORT
STATE OF OREGON
(Please type or print) (Do not write above this line)

CLAC 013232

State Well No. 4/1-16

State Permit No.

(1) OWNER:
Name John Hill
Address Rt. 3 Box 197
Canby, Oregon

(2) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED:
Threaded ☐ Welded ☒
6 " Diam. from 0 ft. to 70 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS:
Perforated? ☐ Yes ☒ No
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:
Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☒ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " "
" " "
Bailer test 20 gal./min. with 10 ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water 54 Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used Bentonite clay & drill cuttings
Well sealed from land surface to 20 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal none sacks
Number of sacks of bentonite used in well seal 1 sacks
Brand name of bentonite Prinville
Number of pounds of bentonite per 100 gallons of water 100 lbs./100 gals.
Was a drive shoe used? ☒ Yes ☐ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Clackamas Driller's well number 1
¼ ¼ Section 16 T. 4S R. 1E W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 35 ft.
Static level 40 ft. below land surface. Date 4-8-72
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:
Diameter of well below casing 6
Depth drilled 70 ft. Depth of completed well 70 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
Brown top soil	0	2	
Brown clay	2	20	
Brown cement gravel	20	45	
Brown clay	45	69	
Brown sand and gravel	69	70	

Work started 4-5 1972 Completed 4-8 1972
Date well drilling machine moved off of well 4-8 1972

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] William D. Christenson Jr. (Drilling Machine Operator) Date 4-8, 1972
Drilling Machine Operator's License No. 500

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name William D. Christenson Jr. (Person, firm or corporation) (Type or print)
Address P.O. Box 343 Hubbard, Oregon
[Signed] William D. Christenson Jr. (Water Well Contractor)
Contractor's License No. 511 Date 4-8, 1972

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119