

NOTICE TO WATER WELL CONTRACTOR: The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON within 30 days from the date of well completion.

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

JUN - 6 1977

State Well No. 45/1E-18
WATER RESOURCES DEPT.
SALEM, OREGON
State Permit No. _____

013511

(1) OWNER:
Name ERRIC ROSS
Address 26851 S. BARLOW RD. CANBY OREGON

(2) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL: Rotary Cable Dug
Driven Jetted Bored
(4) PROPOSED USE (check): Domestic Industrial Municipal Irrigation Test Well Other

(5) CASING INSTALLED:
6" Diam. from +1 ft. to 120 ft. Gage 250"
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(6) PERFORATIONS: Perforated? Yes No.
Type of perforator used _____
Size of perforations _____ in. by _____ in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(7) SCREENS: Well screen installed? Yes No
Manufacturer's Name JOHNSON
Type _____ Model No. _____
Diam. 5 Slot size 20 Set from 120 ft. to 125 ft.
Diam. 5 Slot size 25 Set from 125 ft. to 130 ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? _____
Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.
" " " " " " " " " " " "
" " " " " " " " " " " "
Ballor test 50 gal./min. with 35 ft. drawdown after 1 hrs.
Artesian flow _____ g.p.m.
Temperature of water _____ Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION: Well seal—Material used BENTONITE
Well sealed from land surface to 25 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 0 sacks
Number of sacks of bentonite used in well seal 3 sacks
Brand name of bentonite YELLOWSTONE
Number of pounds of bentonite per 100 gallons of water 200 lbs./100 gals.
Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(10) LOCATION OF WELL:
County CLACKAMAS Driller's well number ~~386~~ 385
_____ 1/4 Section 18 T. 4S R. 1E W.M.
Bearing and distance from section or subdivision corner _____

(11) WATER LEVEL: Completed well.
Depth at which water was first found 119 ft.
Static level 37 ft. below land surface. Date 5/9/77
Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG: Diameter of well below casing _____
Depth drilled 134 ft. Depth of completed well 130 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
TOP SOIL	0	2	
BROWN CLAY	2	10	
SAND AND BROWN CLAY	10	30	
BROWN SAND AND SILT	30	42	
SOFT BLUE CLAY	42	48	
SAND SOME CLAY	48	63	
CEMENTED GRAVEL	63	78	
LOOSE GRAVEL	78	86	
BLUE CLAY	86	92	
SOFT BLUE SANDSTONE	92	94	
BROWN CLAY	94	100	
BLUE CLAY	100	119	
SOFT BLUE SANDSTONE	119	127	37
LOOSE SAND	127	129	37
BLUE CLAY	129	134	

Work started 5/5 1977 Completed 5/9 1977
Date well drilling machine moved off of well 5/9 1977

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] C. Keller Date 5/12, 1977
(Drilling Machine Operator)
Drilling Machine Operator's License No. 329

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name KELLER WELL DRILLING CO.
(Person, firm or corporation) (Type or print)
Address 6350 SE BROWNLEE, MILWAUKIE
[Signed] C. Keller (Water Well Contractor)
Contractor's License No. 462 Date 5/12, 1977