

Dia. of drilled well below 40ft is 12"

CLAC  
013357

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy  
of this report are to be  
filed with the  
STATE ENGINEER, SALEM, OREGON 97310  
within 30 days from the date  
of well completion.

WATER WELL REPORT  
STATE OF OREGON  
(Please type or print)

State Well No. 4/1-19 E  
State Permit No.

(1) OWNER:

Name Dale Matzke  
Address Box 352 Ferry Rd.  
Cany Ore.

(2) LOCATION OF WELL:

County Clackamas Driller's well number  
W 1/4 NW 1/4 Section 19 T. 49 R. 1E W.M.  
Bearing and distance from section or subdivision corner  
660 FT E of The SW Corner of  
The NW 1/4 of Sec 19 T49 R 1E of  
W.M.

(3) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon   
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal  Irrigation  Test Well  Other

(5) TYPE OF WELL:

Rotary  Driven  Cable  Jetted  Dug  Bored

(6) CASING INSTALLED:

Threaded  Welded   
12" Diam. from 0 ft. to 30 ft. Gage 1250  
8" Diam. from 0 ft. to 250 ft. Gage 1250

(7) PERFORATIONS:

Perforated?  Yes  No  
Type of perforator used Torch slots  
Size of perforations 1/8 in. by 6 in.  
720 perforations from 70 ft. to 250 ft.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.

(8) SCREENS:

Well screen installed?  Yes  No  
Manufacturer's Name  
Type Model No.  
Diam. Slot size Set from ft. to ft.  
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Grout  
Depth of seal 1.0 ft. Was a packer used? No  
Diameter of well bore to bottom of seal 1.6 in.  
Were any loose strata cemented off?  Yes  No  
Was a drive shoe used?  Yes  No  
Was well gravel packed?  Yes  No Size of gravel: 3/8  
Gravel placed from 70 ft. to 250 ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? silt depth of strata 6.5 to 7.5  
Method of sealing strata off PIPE

(10) WATER LEVELS:

Static level 23 ft. below land surface Date 3-27-66  
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom? Driller  
Yield: 250 gal./min. with 127 ft. drawdown after 6 hrs.  
" 300 " 187 " 6 "  
" " " " " "  
" " " " " "  
Bailer test gal./min. with ft. drawdown after hrs.  
Artesian flow g.p.m. Date  
Temperature of water 93 Was a chemical analysis made?  Yes  No

(12) WELL LOG:

Diameter of well below casing  
Depth drilled 250 ft. Depth of completed well 250 ft.  
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top soil	0	15
sand (Brown)	15	45
sand & silt (Blue)	45	65
Block silt & fine sand (Black)	65	75
Cement Gravel Tight	75	85
Cement Gravel some water	85	92
Silt & Fine sand (yellow)	92	110
Clay Green	110	115
Clay Blue	115	132
sand water	132	135
Clay (Blue)	135	140
sand & clay (some water)	140	152
Clay (Blue)	152	165
silt & sand (some water)	165	175
silt (maroon with Hard Shells)	175	180
sand (water)	180	185
Clay (Blue)	185	200
Clay (Dark)	200	220
sand water	220	230
Clay (Blue)	230	241
sand streaks in clay (some water)	241	250

Work started December 19 65 Completed Mar 22 1966  
Date well drilling machine moved off of well 3-22 1966

(13) PUMP:

Manufacturer's Name  
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report true to the best of my knowledge and belief.

NAME John Beck well drilling  
(Person, firm or corporation)  
Address Rt. 3 Box 105 Canby Ore.  
Drilling Machine Operator's License No. 437  
[Signed] John W Beck  
(Water Well Contractor)  
Contractor's License No. 1149 Date Mar 23, 1966