

CLAC

013433

RECEIVED

JUN 15 1967 WATER WELL REPORT

4/1-20 @

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON within 30 days from the date of well completion.

STATE OF OREGON STATE ENGINEER (Please type or print) SALEM OREGON G-6496 G-3967

State Well No. 4/1-20 @ State Permit No.

(1) OWNER:

Name Midway Nurseries Inc
Address Rt 2 Box H 2
Hclaira Ore Phone 651 2479

(2) LOCATION OF WELL:

County Clackamas Driller's well number
SW 1/4 SE 1/4 Section 20 T. 4 R. 1E. W.M.
Bearing and distance from section or subdivision corner
205 FT N of 92 FT W of the
SE Corner of the SW 1/4 of
Sec 20.

(3) TYPE OF WORK (check):

New Well [X] Deepening [ ] Reconditioning [ ] Abandon [ ]
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [X] Industrial [ ] Municipal [ ]
Irrigation [X] Test Well [ ] Other [ ]

(5) TYPE OF WELL:

Rotary [ ] Driven [ ]
Cable [X] Jetted [ ]
Dug [ ] Bored [ ]

(6) CASING INSTALLED:

16" Diam. from 0 ft. to 5.5 ft. Gage 250
8" Diam. from 0 ft. to 2.13 ft. Gage 258

(7) PERFORATIONS:

Perforated? [ ] Yes [ ] No
Type of perforator used Torch Slotted
Size of perforations 1/8 in. by 6 in.
590 perforations from 70 ft. to 2.13 ft.

(8) SCREENS:

Well screen installed? [ ] Yes [X] No
Manufacturer's Name
Model No.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal GROUT
Depth of seal 50 ft. Was a packer used? NO
Diameter of well bore to bottom of seal 18 1/4 in.
Were any loose strata cemented off? [ ] Yes [X] No Depth
Was a drive shoe used? [X] Yes [ ] No
Was well gravel packed? [X] Yes [ ] No Size of gravel: 3/4 X 1/4 X 1/8
Gravel placed from 2.13 ft. to TOP ft.
Did any strata contain unusable water? [ ] Yes [X] No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 20 ft. below land surface Date 6-12-67
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? [X] Yes [ ] No If yes, by whom? Miller
Yield: 183 gal./min. with 148 ft. drawdown after 8 hrs.

(12) WELL LOG:

Diameter of well below casing
Depth drilled 213 ft. Depth of completed well 213 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns: MATERIAL, FROM, TO. Rows include: TOP SOIL, Dark clay silt & clay, Cement gravel, Blue clay & silt, Fine sand & silt, Blue clay & silt, Dark blue clay, Gray clay, Fine sand, Dark clay, silt & fine sand, Gray clay, Blue clay & silt, Reddish Brown silt, Sand & silt, Blue clay.

Application No. G-3967

Permit No.

Work started May 12 1967 Completed June 11 1967
Date well drilling machine moved off of well June 12 1967

(13) PUMP:

Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME John Beck Well Drilling
(Person, firm or corporation) (Type or print)

Address 954 S Fry St Canby Ore.

Drilling Machine Operator's License No. H 37

[Signed] John W Beck
(Water Well Contractor)

Contractor's License No. H 49 Date June 13, 1967