

**WATER WELL REPORT**  
STATE OF OREGON

RECEIVED

MAY 7 1981

CLAC 1375

Sp. Standards  
request letter  
states 8" casing

State Well No. 15/55-301d

15/55-301d

CLAC 01375

WATER RESOURCES DEPT  
SALEM, OREGON

State Permit No.

**(1) OWNER:**

Name Camp Fire Inc.  
Address 718 W Burnside  
City Portland State Oregon

**(2) TYPE OF WORK (check):**

New Well  Deepening  Reconditioning  Abandon

If abandonment, describe material and procedure in Item 12.

**(3) TYPE OF WELL:**

Rotary Air  Driven   
Rotary Mud  Dug   
 Bored

**(4) PROPOSED USE (check):**

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other   
Thermal: Withdrawal  ReInjection

**(5) CASING INSTALLED:**

Steel  Plastic   
Threaded  Welded   
35" Diam. from 0 ft. to 35 ft. Gauge 250  
+1" Diam. from +1 ft. to ft. Gauge

**LINER INSTALLED:**

" Diam. from ft. to ft. Gauge

**(6) PERFORATIONS:**

Perforated?  Yes  No

Type of perforator used

Size of perforations in. by in.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.

**(7) SCREENS:**

Well screen installed?  Yes  No

Manufacturer's Name  
Type Model No.  
Diam. Slot Size Set from ft. to ft.  
Diam. Slot Size Set from ft. to ft.

**(8) WELL TESTS:**

Drawdown is amount water level is lowered below static level

Was a pump test made?  Yes  No If yes, by whom?  
gal/min. with ft. drawdown after hrs.  
Air test gal./min. with drill stem at ft. hrs.  
Bailer test 40 gal./min. with 30 ft. drawdown after 4 hrs.  
Artesian flow g.p.m.  
Temperature of water Depth artesian flow encountered ft.

**(9) CONSTRUCTION:**

Special standards: Yes  No

Well seal—Material used 40 sacks cement  
Well sealed from land surface to 200 lb bent. ft.  
Diameter of well bore to bottom of seal in.  
Diameter of well bore below seal in.  
Number of sacks of cement used in well seal sacks  
How was cement grout placed?

Was pump installed? Type HP Depth ft.  
Was a drive shoe used?  Yes  No Plugs Size: location ft.  
Did any strata contain unusable water?  Yes  No  
Type of Water? depth of strata  
Method of sealing strata off  
Was well gravel packed?  Yes  No Size of gravel: ft.  
Gravel placed from ft. to ft.

**(10) LOCATION OF WELL:**

County Clack. Driller's well number  
SE 1/4 SE 1/4 Section 30 T. 15 R. SE W.M.  
Tax Lot # Lot Blk Subdivision

Address at well location: end of Elsner Rd  
Sandy, Oregon

**(11) WATER LEVEL: Completed well.**

Depth at which water was first found ft.  
Static level 22 ft. below land surface. Date 3/25/81  
Artesian pressure lbs. per square inch. Date

**(12) WELL LOG:**

Diameter of well below casing

Depth drilled No ft. Depth of completed well 118 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Things determined about existing well:			
22 ft static cased to bottom 6" T.C. pipe pipe perforated centered in 6 ft hand dug well			
good water sample after completion of work			
3/4 h.p. sub. pump pump set 105 feet pumping rate 15 g.p.m. pumping level 35 feet			

Work started 3/25 1981 Completed 4-10 1981  
Date well drilling machine moved off of well 4-10 1981

**Drilling Machine Operator's Certification:**

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.  
[Signed] Ted Pulliam Date 4/25, 1981.  
(Drilling Machine Operator)

Drilling Machine Operator's License No. 813

**Water Well Contractor's Certification:**

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Ted Pulliam Well Drilling  
(Person, firm or corporation) (Type or print)  
Address 4245 W Powell Gresham, Ore.

[Signed] Ted Pulliam  
(Water Well Contractor)

Contractor's License No. 616 Date 4-25 1981