

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

CLACK
013921

WATER WELL REPORT

Well #3

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

STATE OF OREGON
(Please type or print)
(Do not write above this line)

State Well No. 4/2-17 A

State Permit No. _____

G-4229

(1) OWNER:

Name MULINO WATER DIST NO. 1
Address MULINO, ORE.

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded
16" Diam. from 0 ft. to 18 ft. Gage 312
12" Diam. from 0 ft. to 237 ft. Gage 330
" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated? Yes No.
Type of perforator used STAR
Size of perforations 3/8 in. by 1 1/4 in.
400 perforations from 218 ft. to 230 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WATER LEVEL: Completed well.

Static level 41 ft. below land surface Date 11/17/67
Artesian pressure _____ lbs. per square inch Date _____

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? STRASSER
Yield: 350 gal./min. with 78 ft. drawdown after 10 hrs.
300 " " 71 " " 11 "
" 250 " " 63 " " 12 "
Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water 54.0 Was a chemical analysis made? Yes No

(10) CONSTRUCTION:

Well seal—Material used CEMENT GROUT
Depth of seal 35 ft.
Diameter of well bore to bottom of seal 16 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(11) LOCATION OF WELL:

County CLACK Driller's well number 4261
NE 1/4 NE 1/4 Section 17 T. 45 R. 2E W.M.

Bearing and distance from section or subdivision corner _____

(12) WELL LOG:

BACKFILLED TO 237 FT.
Diameter of well below casing _____
Depth drilled 278 ft. Depth of completed well 237 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
CLAY	0	8	
BOULDERS	8	13	
CLAY AND GRAVEL	13	18	
RED CLAY	18	27	
WHITE CLAY	27	47	
BROWN SAND	47	51	
GREY CLAY	51	54	
BLUE CLAY	54	68	
GRAVEL (FINE)	68	68	
CLAY (BLUE)	68	144	
CLAY AND GRAVEL	144	162	
BLUE SHALE	162	178	
GREEN CLAY	178	190	
BLUE CLAY	190	207	
SAND	207	210	
SAND AND GRAVEL	210	226	
BLUE CLAY	226	264	
GREY CLAY	264	278	

Work started SEPT 25 1967 Completed NOV 24 1967
Date well drilling machine moved off of well NOV 24 1967

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Carl V Baker Date JAN 10 1968
(Drilling Machine Operator)

Drilling Machine Operator's License No. 190

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME R. STRASSER DEALING CO
(Person, firm or corporation) (Type or print)

Address 5100 SE SUNSET LANE PORTLAND ORE

[Signed] Robert L Strasser
(Water Well Contractor)

Contractor's License No. 10 Date JAN 9 1968