

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

**RECEIVED**  
 JUL 24 1965  
 STATE ENGINEER

WATER WELL REPORT

STATE OF OREGON  
 (Please type or print)

CLAC  
 014253  
 3248

State Well No. 4/2E-30  
 State Permit No. R

(1) OWNER:

Name V. H. STEINHAUSER  
 Address Rt. 3 - Box 277 - CANBY ORE.

(2) LOCATION OF WELL:

County CLATSOP Driller's well number  
SE 1/4 SE 1/4 Section T. R. W.M.  
 Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon   
 Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal   
 Irrigation  Test Well  Other

(5) TYPE OF WELL:

Rotary  Driven   
 Cable  Jetted   
 Dug  Bored

(6) CASING INSTALLED:

Threaded  Welded   
10" Diam. from 7.1 ft. to 4.58 ft. Gage 250  
 " Diam. from " ft. to " ft. Gage  
 " Diam. from " ft. to " ft. Gage

(7) PERFORATIONS:

Perforated?  Yes  No  
 Type of perforator used mills  
 Size of perforations 3/8 in. by 2 1/2 in.  
5.36 perforations from 40 ft. to 122 ft.  
72 perforations from 129 ft. to 136 ft.  
20 perforations from 204 ft. to 225 ft.  
27 perforations from 453 ft. to 456 ft.

(8) SCREENS:

Well screen installed?  Yes  No  
 Manufacturer's Name \_\_\_\_\_ Model No. \_\_\_\_\_  
 Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
 Diam. Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal DRILL CUTTINGS & BENTONITE  
 Depth of seal 35 ft. Was a packer used? No  
 Diameter of well bore to bottom of seal 14 in.  
 Were any loose strata cemented off?  Yes  No Depth \_\_\_\_\_  
 Was a drive shoe used?  Yes  No  
 Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
 Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
 Did any strata contain unusable water?  Yes  No  
 Type of water? \_\_\_\_\_ depth of strata \_\_\_\_\_  
 Method of sealing strata off \_\_\_\_\_

(10) WATER LEVELS:

Static level 15 ft. below land surface Date 7/20/65  
 Artesian pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level  
 Was a pump test made?  Yes  No If yes, by whom? STETTER  
 Yield: 575 gal./min. with 65 ft. drawdown after 14 hrs.  
 " " " " " "  
 " " " " " "  
 Bailer test gal./min. with ft. drawdown after hrs.  
 Artesian flow g.p.m. Date  
 Temperature of water Was a chemical analysis made?  Yes  No

(12) WELL LOG:

Diameter of well below casing 10 in.  
 Depth drilled 500 ft. Depth of completed well 500 ft.  
 Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Clay - Brown	0	30
PARTLY CEMENTED GRAVEL	30	64
BLACK SAND	64	66
COURSE GRAVEL & BROWN CLAY	66	83
BROWN - CLAY	83	86
COURSE GRAVEL	86	97
BROWN CLAY & GRAVEL	97	120
BLACK SAND & "	120	122
BROWN - CLAY	122	129
" " & SAND	129	136
CLAY - GRAY	136	204
BLACK SAND W.D.	204	225
CLAY - BROWN	225	255
" GRAY	255	268
SAND & GRAVEL WITH BROWN	268	277
CLAY - GRAY	277	285
" " & SAND	285	292
" " "	292	302
" " & " & GRAVEL	302	380
" BROWN	380	392
" GRAY	392	438
" BLUE	438	442
CLAY STONE - BROWN	442	453
BLACK SAND & SMALL GRAVEL	453	456
Work started <u>5/27/65</u> 19	Completed <u>7/20/65</u> 19	
Date well drilling machine moved off of well	" " " "	19

456 TO 500 - CLAY STONE - BROWN

(13) PUMP:

Manufacturer's Name \_\_\_\_\_  
 Type: \_\_\_\_\_ H.P. \_\_\_\_\_

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME MILLER - ROBINSON & WEST  
 (Person, firm or corporation) (Type or print)

Address 5545 JOSEPH ST. S.E. SALEM ORE

Drilling Machine Operator's License No. 59

[Signed] Harlan R. Miller  
 (Water Well Contractor)

Contractor's License No. 37 Date 7/22/65, 19\_\_\_\_