

RECEIVED well #2
APR 25 1967

CLAG

014257

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

WATER WELL REPORT
STATE OF OREGON

STATE OF OREGON
(Please type or print)

State Well No. 4/2-314
State Permit No. G-4228

(1) OWNER:

Name Dick Moorehouse
Address Molalla, Oregon

(2) LOCATION OF WELL:

County Clackamas Driller's well number
1/4 1/4 Section 31 T. 4S R. 2E W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal Rotary Driven
Irrigation Test Well Other Cable Jetted
Dug Bored

(5) TYPE OF WELL:

(6) CASING INSTALLED:

Threaded Welded
12" Diam. from 0 ft. to 168 ft. Gage 1/4"
8" Diam. from 165 ft. to 320 ft. Gage 1/4"
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? Yes No

Type of perforator used Millknife
Size of perforations 3/8 in. by 4 in.
50 perforations from 65 ft. to 69 ft.
81 perforations from 82 ft. to 89 ft.
64 perforations from 120 ft. to 126 ft.
70 perforations from 128 ft. to 133 ft.
8 perforations from 161 ft. to 163 ft.

(8) SCREENS:

Well screen installed? Yes No

Manufacturer's Name
Type Model No.
Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Puddled Mud
Depth of seal 20 ft. Was a packer used? no
Diameter of well bore to bottom of seal 18 in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 21 ft. below land surface Date 4/20/67
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? driller
Yield: 500 gal./min. with 57 ft. drawdown after 4 hrs.

Baller test gal./min. with ft. drawdown after hrs.

Artesian flow g.p.m. Date

Temperature of water Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing

Depth drilled 320 ft. Depth of completed well 320 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Soil	0	3
Brown clay	3	8
Cement gravel	8	134
Brown sticky clay	134	146
Blue sandy clay	146	161
Gravel	161	163
Blue sandy clay	163	181
Coarse red sand	181	186
Shale rock (blue)	186	228
Sticky shale	228	247
Grey sandy clay	247	255
Hard sand	255	260
Brown sandy shale	260	282
Sand	282	290
Blue shale	290	300
Grey shale	300	315
Blue shale	315	320

Additional perforations

Torch perforations in 8" liner (1/4" x 12")
15 perforations from 179' to 182'
20 perforations from 255' to 260'
10 perforations from 280' to 282'
10 perforations from 299' to 301'

Work started January 10 19 67 Completed April 20 19 67

Date well drilling machine moved off of well April 20 19 67

(13) PUMP:

Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME John Truman Miller
(Person, firm or corporation) (Type or print)

Address P O Box 42 Hubbard, Oregon

Drilling Machine Operator's License No. 26

[Signed] John Truman Miller
(Water Well Contractor)

Contractor's License No. 277 Date April 21 1967