NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED JUN 28 1971 STATE ENGINEER SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

CLAC 014275

State Well No. 4/2-32

State Permit No.

(1) OWNER:
Name Irvin Stalhuecker
Address RT 1 Colton

(2) TYPE OF WORK (check):
New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☑ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☑ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED: Threaded ☐ Welded ☑
6" Diam. from 0 ft. to 64' ft. Gage 17 lb
5 9/16 OD Diam. from 52 ft. to 82 ft. Gage 1060
" Diam. from ft. to ft. Gage

(6) PERFORATIONS: Perforated? ☑ Yes ☐ No.
Type of perforator used
Size of perforations 3/8 in. by 12" in.
3 perforations from 67 ft. to 79 ft.
3 perforations from 67 ft. to 77 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☑ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.
Static level 36' ft. below land surface Date June 22
Artesian pressure lbs. per square inch Date

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☐ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 25 gal./min. with 31 ft. drawdown after 1/2 hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? ☐ Yes ☑ No

(10) CONSTRUCTION:
Well seal—Material used Bentonite Clay
Depth of seal 36' ft.
Diameter of well bore to bottom of seal 10 in.
Were any loose strata cemented off? ☐ Yes ☑ No Depth
Was a drive shoe used? ☑ Yes ☐ No
Did any strata contain unusable water? ☐ Yes ☑ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☐ No Size of gravel:
Gravel placed from ft. to ft.

(11) LOCATION OF WELL:
County Clackamas Driller's well number 246
¼ ¼ Section 32 T. 4S R. 4E W.M.
Bearing and distance from section or subdivision corner

(12) WELL LOG: Diameter of well below casing 6
Depth drilled 86 ft. Depth of completed well 84 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Clay Red Brown	0	2	
Decomposed Rock	2	32	
Mud Flow	32	40	
Rock Black	40	44	
Hard Mud Flow	44		
with Scattered Rock			
Sandy Decomposed Rock	82	86	

Work started June 17 1971 Completed June 22 1971
Date well drilling machine moved off of well " " 19 "

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Robert P. Collins Date June 23, 1971
(Drilling Machine Operator)
Drilling Machine Operator's License No. 174

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME Collins Drilling Co
(Person, firm or corporation) (Type or print)
Address RT 1 Box 368 Molino Ore
[Signed] Robert P. Collins
(Water Well Contractor)
Contractor's License No. 204 Date June 24, 1971

(USE ADDITIONAL SHEETS IF NECESSARY)