NOTICE TO WATER WELL CONTRACTOR The original and fi WATER WELL REPORT of this report are STATE ENGINEER, SALEM OREGON 97310 RSTATE OF OREGON within 30 days the state of the State Well No. 4/2-32 old within 30 days from the date 1 14 of well completion. (Do not write above this line) State Permit No. (1) OWNER: (11) LOCATION OF WELL: Driller's well number Name Wesley Hamilton County Clackamas Address Route 2. Box 495. Molalla. Ore. 97038 14 SE 34 Section 32 T. 1,5 Bearing and distance from section or subdivision corner (2) TYPE OF WORK (check): New Well Deepening [Reconditioning [Abandon [1] If abandonment, describe material and procedure in Item 12. (3) TYPE OF WELL: (4) PROPOSED USE (check): (12) WELL LOG: Diameter of well below casing Driven 🗌 Rotary Domestic 🔀 Industrial 🗌 Municipal 🗍 Jetted 🔲 116 ft. Depth of completed well 776 Cable Depth drilled Irrigation

Test Well
Other Dug Bored | Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, CASING INSTALLED: Threaded | Welded | with at least one entry for each change of formation. Report each change 6." Diam. from 0 ft. to 107 ft. Gage 0.250 in position of Static Water Level as drilling proceeds. Note drilling rates, 5 9/160 Deliber 104 st to 116 st Gage 10 MATERIAL. ft. to ft. Gage 5 n Clay, tan 12 Clay and gravel, tan PERFORATIONS: Perforated? TY Yes | No. 67 12 Gravel and boulders, cemented Type of perforator used Torch 67 75 Clay, tan 1/8 in. by 12 Size of perforations 112 Gravel, cemented 75 18 18 perforations from 105 ft. to 112 Clay, sandy, grey 116 perforations from _____ ft. to _____ ft. perforations from ft. to ft. perforations from ft. to ft. (7) SCREENS: Well screen installed? [] Yes [X] No Manufacturer's Name Model No. Diam. Slot size Set from ft. to Diam. Slot size Set from ft. to ... (8) WATER LEVEL: Completed well. Static level 18 ft. below land surface Date 3-15-69 kian pressure lbs. per square inch Date Drawdown is amount water level is lowered below static level (9) WELL TESTS: Was a pump test made? [Yes No If yes, by whom? 19 69 Completed Mar. 15 Work started 169 gal./min. with ft. drawdown after hrs. Date well drilling machine moved off of well 169 Mar 17 Drilling Machine Operator's Certification: This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief. 35 gal./min. with 64 ft. drawdown after 1 g.p.m. Date [Signed] June 1 1 Mc (Orilling Machine Opera Mark Date Mar. 21, 1969 Temperature of water

□ Yes
□ No (10) CONSTRUCTION: Drilling Machine Operator's License No. 398 Well seal-Material used Bentonita Depth of seal Water Well Contractor's Certification: 10 in. This well was drilled under my jurisdiction and this report is Diameter of well bore to bottom of seal true to the best of my knowledge and belief. Were any loose strata cemented off? Yes W No Depth ... NAME Steinman Bros.
(Person, firm or corporation) Was a drive shoe used? ② Yes ☐ No (Type or print) Did any strata contain unusable water? Yes V No Address15112 S.E.McLoughlin, Milwaukie, Ore, 97222 depth of strata Type of water?

Contractor's License No. I Date March 21 1969

Size of gravel:

at. to

Method of sealing strata off

Gravel placed from

Was well gravel packed? 🗌 Yes 🗓 No