

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

RECEIVED

APR 23 1965 WATER WELL REPORT

CLAC 014617

3/4-24 H

STATE ENGINEER, SALEM, OREGON 97310

STATE OF OREGON (Please type or print)

State Well No. State Permit No.

(1) OWNER:

Name Barney Lucas Address Rt 2 Box 600 Estacada Ore

(2) LOCATION OF WELL:

County Clackamas Driller's well number 11-65 SE 1/4 N 1/4 Section 24 T. 35 R. 4E W.M. Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well X Deepening Reconditioning Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal Irrigation Test Well Other Housing Development X

(5) TYPE OF WELL:

Rotary Cable Dug Driven Jetted Bored X

(6) CASING INSTALLED:

6" Diam. from 0 ft. to 130 ft. Gage 1.250

(7) PERFORATIONS:

Type of perforator used Mills Knife Perforated? X Yes No Size of perforations 1 1/4 in. by 2 in. 35 perforations from 70 ft. to 77 ft. 15 perforations from 85 ft. to 88 ft. 60 perforations from 112 ft. to 126 ft.

(8) SCREENS:

Well screen installed? X Yes No Manufacturer's Name Type Model No. Slot size Set from ft. to ft. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Bentonite Depth of seal 35 ft. Was a packer used? Yes Diameter of well bore to bottom of seal 10 in. Were any loose strata cemented off? X Yes No Depth Was a drive shoe used? X Yes No Was well gravel packed? X No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusable water? X Yes No Type of water? depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level 50 ft. below land surface Date 3/18/65 Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? X Yes No If yes, by whom Steinman Bros Yield: 115 gal./min. with 72 ft. drawdown after 8 hrs.

(12) WELL LOG:

Diameter of well below casing

Depth drilled 130 ft. Depth of completed well 130 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Entries include clay Brown, cement gravel Brown, siltstone Brown, cement gravel & Boulders, sandy clay Brown, Brown sandy clay, sand gravel Fine, yellow sand Brown sand, sand gravel Brown, cement sand gravel, grey sandstone, grey clay.

Work started 3/16/65 Completed 3/20/65 Date well drilling machine moved off of well 3/23/65

(13) PUMP:

Manufacturer's Name Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Steinman Bros (Person, firm or corporation) (Type or print) Address Milwaukie 22 Dr Drilling Machine Operator's License No. 67 [Signed] Steinman Bros (Water Well Contractor) Contractor's License No. 1 Date 4/12/65